

NECA 230-2016

Standard for Selecting, Installing, and Maintaining

Electric Motors and Motor Controllers (1000 Volts and Less)

AN AMERICAN NATIONAL STANDARD




Published by
National Electrical Contractors Association

NECA 230-2016

Standard for Selecting, Installing, and Maintaining

Electric Motors and Motor Controllers (1000 Volts and Less)

**An American
National Standard**



Published by
National Electrical
Contractors Association



Revision History	
NECA 230-2003 originally published	08/2003
NECA 230-2010 revised	06/2010
NECA 230-2016 revised	04/2016

NOTICE OF COPYRIGHT

This document is copyrighted by NECA

ISBN: 978-1-944148-14-0

©2016. Reproduction of these documents either in hard copy or soft (including posting on the web) is prohibited without copyright permission. For copyright permission to reproduce portions of this document, please contact NECA Standards & Safety at (301) 215-4549, or send a fax to (301) 215-4500.

OR

National Electrical Contractors Association
3 Bethesda Metro Center, Suite 1100
Bethesda, Maryland 20814
(301) 657-3110

Table of Contents

- Foreword.....vii**
- 1. Scope 1**
 - 1.1 Products and Applications Included1
 - 1.2 Regulatory and Other Requirements1
 - 1.3 Mandatory Requirements, Permissive Requirements, Quality and Performance Recommendations, Explanatory Material, and Informative Annexes.....1
- 2. Definitions 3**
- 3. Safety 4**
 - 3.1 General4
 - 3.2 Safe Work Practices5
 - 3.3 Personal Protective Equipment (PPE)5
 - 3.4 De-Energizing Electrical Equipment5
 - 3.5. Rotating Machines6
- 4. Receiving, Handling, and Storage 7**
 - 4.1 Receiving7
 - 4.2 Handling7
 - 4.3 Storage.....8
- 5. Selecting Motors 10**
 - 5.1 General.....10
 - 5.2 Locating Motors11
 - 5.3 Hazardous (Classified) Locations.....11
 - 5.4 Foundation and Mounting11
- 6. Motor Branch Circuit Conductors 13**
 - 6.1 Determining Motor Full Load Current (FLC)13
 - 6.2 Branch Circuit Conductors for a Single Motor.....13
 - 6.3 Feeder Circuit Conductors for Multiple Motors.....14
 - 6.4 Conductor Temperature Ratings.....14
- 7. Motor Branch-Circuit Short-Circuit and Ground-Fault Protection..... 15**
 - 7.1 Locked-Rotor Current (LRC)15
 - 7.2 Short-Circuit and Ground-Fault Ratings and Settings.....15
 - 7.3 Individual Motor Circuits.....16
 - 7.4 Taps From Feeders.....16
 - 7.5 More Than One Motor or Motor(s) and Other Loads.....16
 - 7.6 Single-Phasing16

8. Motor and Branch Circuit Overload Protection	18
8.1 Continuous Duty Motors	18
8.2 Motor Service Factor.....	18
8.3 Separate Overload Devices	18
8.4 Motor Temperature Ratings	19
8.5 Fuses as Overload Protection.....	19
8.6 Motor Protection Relays	19
8.7 Variable Frequency Drives (VFDs).....	20
9. Disconnecting Means for Motors and Controllers	21
9.1 Motors.....	21
9.2 Controllers.....	21
9.3 Types of Motor Disconnects.....	22
10. Motor Control Circuits	23
10.1 Source of Supply.....	23
10.2 Overcurrent Protection.....	23
10.3 Control Circuit Transformer	23
10.4 Disconnection.....	23
10.5 Protection from Physical Damage.....	24
11. Motor Controllers	25
11.1 Rating.....	25
11.2 Controller Enclosure	26
11.3 Controller Classification	26
11.4 Wiring Space in Enclosures	26
11.5 Controller Grounding.....	26
11.6 Variable Frequency Drives (VFDs).....	27
12. Motor Terminal Housings.....	28
12.1 Dimensions and Space	28
12.2 Equipment Grounding Connections	28
13. Motor Wiring Connections	29
13.1 High-Voltage Connections	29
13.2 Low-Voltage Connections.....	29
13.3 Motor Rotation.....	29
14. Example Three-Phase Motor Installation.....	31
15. Startup and Commissioning.....	33
15.1 Pre-Functional Checks.....	33
15.2 Aligning Motors	33
15.3 Initial Startup	34
15.4 Acceptance Testing	35
16. Electric Motor Maintenance	36
16.1 General.....	36
16.2 Visual Inspections	36

16.3	Cleaning.....	37
16.4	Service and Maintenance	37
Annex A: Tables.....		39
	Motor Starter Selection Data Sheet (<i>Courtesy Square D Company</i>).....	39
	NEC Table 310.15 (B)(16) (<i>Courtesy National Fire Protection Association</i>)	40
	NEC Table 430.10(B) (<i>Courtesy National Fire Protection Association</i>).....	41
	NEC Table 430.12(B) (<i>Courtesy National Fire Protection Association</i>).....	41
	NEC Table 430.52 (<i>Courtesy National Fire Protection Association</i>)	41
	NEC Table 430.72(B) (<i>Courtesy National Fire Protection Association</i>).....	42
	NEC Table 430.247 (<i>Courtesy National Fire Protection Association</i>)	42
	NEC Table 430.248 (<i>Courtesy National Fire Protection Association</i>)	43
	NEC Table 430.249 (<i>Courtesy National Fire Protection Association</i>)	43
	NEC Table 430.250 (<i>Courtesy National Fire Protection Association</i>)	44
	NEC Table 430.251(B) (<i>Courtesy National Fire Protection Association</i>).....	44
Annex B: Wiring Diagrams.....		45
	Wiring Diagram: High Voltage and Low Voltage Delta Motor Windings	45
	Wiring Diagram: High Voltage and Low Voltage Star (Y) Motor Windings.....	45
	Wiring Diagram: One Three-Wire Stop-Start Station.....	46
	Wiring Diagram: Two Three-Wire Stop-Start Station.....	47
	Wiring Diagram: Hand-Off Automatic Control	48
	One-Line Diagram: Motor Installation	49
Annex C: Electrical Testing.....		50
C.1	Insulation Resistance Testing.....	50
C.2	Power Factor Testing	51
C.3	Surge Testing.....	51
C.4	Infrared Scan	51
Annex D: Reference Standards		53

(This foreword is not a part of the standard)

Foreword

National Electrical Installation Standards™ (NEIS™) are intended to improve communication among specifiers, purchasers, and suppliers of electrical construction services. They define a minimum baseline of quality and workmanship for installing electrical products and systems. *NEIS* are intended to be referenced in contract documents for electrical construction projects. The following language is recommended:

Wiring devices should be installed and maintained in accordance with NECA 230-2016, *Standard for Selecting, Installing, and Maintaining Electric Motors and Motor Controllers (1000 Volts and Less)* (ANSI).

Use of *NEIS* is voluntary, and the National Electrical Contractors Association assumes no obligation or liability to users of this publication. Existence of a standard shall not preclude any member or non-member of NECA from specifying or using alternate construction methods permitted by applicable regulations.

This publication is intended to comply with the edition of the National Electrical Code (NEC) in effect at the time of publication. Because they are quality standards, *NEIS* may in some instances go beyond the minimum requirements of the NEC. It is the responsibility of users of this publication to comply with state and local electrical codes when installing electrical products and systems.

Suggestions for revisions and improvements to this standard are welcome. They should be addressed to:

NECA Standards & Safety
3 Bethesda Metro Center, Suite 1100
Bethesda, MD 20814
(301) 215-4521 Telephone
(301) 215-4500 Fax
neis@necanet.org
www.neca-neis.org

To purchase *National Electrical Installation Standards*, contact the NECA Order Desk at (301) 215-4504 tel, (301) 215-4500 fax, or orderdesk@necanet.org. *NEIS* can also be purchased in .pdf download format from www.neca-neis.org/standards.

Copyright ©2016, National Electrical Contractors Association. All rights reserved. Unauthorized reproduction prohibited.

National Electrical Installation Standards, *NEIS*, and the *NEIS* logo are trademarks of the National Electrical Contractors Association. National Electrical Code and NEC are trademarks of the National Fire Protection Association, Quincy, Massachusetts.

1. Scope

1.1 Products and Applications Included

This standard describes recommended procedures for selecting and installing stationary electric motors and motor controllers rated 1000 volts or less. It also covers routine maintenance procedures to be followed after the installation is complete.

1.2 Regulatory and Other Requirements

All information in this publication is intended to conform to the NEC (ANSI/NFPA 70), and, in general, the typical recommendations of electric motor and motor controller manufacturers. Installers shall follow the NEC, applicable state and local codes, manufacturer instructions, and contract documents when installing motors and motor controllers.

Only qualified persons familiar with the construction and operation of motors and motor controllers should perform the work described in this publication. Administrative functions such as receiving, handling, and storing required in Section 4, and other tasks may be performed under the supervision of a qualified person. All work shall be performed in accordance with NFPA 70E, *Standard for Electrical Safety in the Workplace*.

General requirements for installing electrical products and systems are described in NECA 1, *Standard for Good Workmanship in Electrical Construction* (ANSI). Other *NEIS* provide additional guidance for installing particular types of electrical products and systems. A complete list of *NEIS* is provided in Annex D.

1.3 Mandatory Requirements, Permissive Requirements, Quality and Performance Recommendations, Explanatory Material, and Informative Annexes

Mandatory Requirements. Mandatory requirements in manufacturer instructions, or of Codes or other mandatory Standards that may or not be adopted into law, are those that identify actions that are specifically required or prohibited and are characterized by the use of the terms must or must not, shall or shall not, or may not, or are not permitted, or are required, or by the use of positive phrasing of mandatory requirements. Examples of mandatory requirements may equally take the form of, “equipment must be protected . . .,” “equipment shall be protected . . .,” or “protect equipment . . .,” with the latter interpreted (understood) as “(it is necessary to, or, it is required to) protect equipment . . .”

Permissive Requirements. Permissive requirements of manufacturer instructions, or of Codes or other mandatory Standards that may or not be adopted into law, are those that identify actions that that are allowed but not required, or are normally used to describe options or alternative means and methods, and are characterized in this Standard by the use of the terms may, or are permitted, or are not required.

Quality and Performance Recommendations. Quality and performance recommendations identify actions that are recommended or not recommended to improve the overall quality or performance of the installation and are characterized by the use of the term should or should not.