



PROCESS
INDUSTRY
PRACTICES

COMPLETE REVISION
October 2022

Structural

PIP STS02380
Application of ACI 336.1-01,
Specification for the Construction of
Drilled Piers

PURPOSE AND USE OF PROCESS INDUSTRY PRACTICES

In an effort to minimize the cost of process industry facilities, this Practice has been prepared from the technical requirements in the existing standards of major industrial users, contractors, or standards organizations. By harmonizing these technical requirements into a single set of Practices, administrative, application, and engineering costs to both the purchaser and the manufacturer should be reduced. While this Practice is expected to incorporate the majority of requirements of most users, individual applications may involve requirements that will be appended to and take precedence over this Practice. Determinations concerning fitness for purpose and particular matters or application of the Practice to particular project or engineering situations should not be made solely on information contained in these materials. The use of trade names from time to time should not be viewed as an expression of preference but rather recognized as normal usage in the trade. Other brands having the same specifications are equally correct and may be substituted for those named. All Practices or guidelines are intended to be consistent with applicable laws and regulations including OSHA requirements. To the extent these Practices or guidelines should conflict with OSHA or other applicable laws or regulations, such laws or regulations must be followed. Consult an appropriate professional before applying or acting on any material contained in or suggested by the Practice.

This Practice is subject to revision at any time.

© Process Industry Practices (PIP), Construction Industry Institute, The University of Texas at Austin, 3925 West Braker Lane (R4500), Austin, Texas 78759. PIP Member Companies and Subscribers may copy this Practice for their internal use. Changes or modifications of any kind are not permitted within any PIP Practice without the express written authorization of PIP. Authorized Users may attach addenda or overlays to clearly indicate modifications or exceptions to specific sections of PIP Practices. Authorized Users may provide their clients, suppliers and contractors with copies of the Practice solely for Authorized Users' purposes. These purposes include but are not limited to the procurement process (e.g., as attachments to requests for quotation/purchase orders or requests for proposals/contracts) and preparation and issue of design engineering deliverables for use on a specific project by Authorized User's client. PIP's copyright notices must be clearly indicated and unequivocally incorporated in documents where an Authorized User desires to provide any third party with copies of the Practice.

PUBLISHING HISTORY

<i>August 1996</i>	<i>Issued</i>	<i>January 2017</i>	<i>Complete Revision</i>
<i>June 2002</i>	<i>Complete Revision</i>	<i>October 2022</i>	<i>Complete Revision</i>
<i>February 2009</i>	<i>Complete Revision</i>		



PIP STS02380
Application of ACI 336.1-01,
Specification for the Construction of
Drilled Piers

Table of Contents

Scope2

References2
 Industry Codes and Standards.....2

Definitions.....2

Requirements3

Scope

This Practice supplements *ACI 336.1-01, Specification for the Construction of Drilled Piers*. Together, this Practice and *ACI 336.1-01* provide requirements for drilled pier construction.

The requirements of *ACI 336.1-01*, as modified and supplemented by this Practice, are adopted by this Practice for the construction of drilled piers. Common industry terminology may also refer to drilled piers as caissons or drilled shafts.

References

Applicable requirements of the following industry standard shall be considered an integral part of this Practice. Short title is used herein where appropriate.

Industry Codes and Standards

- American Concrete Institute (ACI)
 - *ACI 336.1-01 - Specification for the Construction of Drilled Piers*

Definitions

Terminology used in the additions and modifications to the requirements of *ACI 336.1-01* presented in the Requirements section of this Practice is the same as terminology used in *ACI 336.1-01* with the exception of the PIP terms “purchaser” and “owner” which are presented in one term in *ACI 336.01* as “Owner.” PIP terminology and definitions that are considered equivalent to terminology used in *ACI 336.1-01* are provided for reference below:

constructor: Party responsible for supplying materials, equipment, tools, supervision, and labor for installation of drilled piers in accordance with contract documents. The term constructor applies also to constructor’s subcontractor(s) and vendor(s). *Referred to as “Contractor” in ACI 336.1-01.*

contract documents: Any and all documents, including codes, studies, design drawings, specifications, sketches, practices, and data sheets, that purchaser or engineer of record has transmitted or otherwise communicated, either by incorporation or reference, and made part of the legal contract agreement or purchase order between purchaser and constructor. *Referred to as “Contract Documents” in ACI 336.1-01.*

engineer of record: Purchaser’s authorized representative with overall authority and responsibility for engineering design, quality, and performance of civil works, structures, foundations, materials, and appurtenances described in contract documents. Engineer of record is licensed as defined by laws of the locality in which the work is to be constructed, and is qualified to practice in the specialty discipline required for the work described in contract documents. *Referred to as “Owner’s Representative” in ACI 336.1-01.*

geotechnical engineer: Professional engineer responsible for performing geotechnical investigation and/or geotechnical consulting during design and installation of drilled piers. *Referred to as “Owner’s Representative-Geotechnical Engineer” in ACI 336.1-01.*

inspector: Party responsible for verifying quality of all materials, installations, and workmanship furnished by constructor and any subcontractors or vendors. Inspector is qualified by training