



PROCESS  
INDUSTRY  
PRACTICES

TECHNICAL REVISION  
*December 2023*

***Process Control***

**PIP PCCA001**  
**Fixed Gas Detection Design Criteria**

---

## PURPOSE AND USE OF PROCESS INDUSTRY PRACTICES

This Practice has been prepared by harmonizing technical requirements from existing standards of major industrial operators, contractors, and standards development organizations. While this Practice is intended to incorporate the majority of requirements, individual applications may have requirements which take precedence over this Practice. Determinations concerning fitness for purpose or application of this Practice to specific project or engineering situations should not be made solely on information contained in this Practice. All Practices are intended to be consistent with applicable laws and regulations. Should this Practice conflict with applicable laws or regulations, such laws or regulations must be followed. Consult an appropriate professional before applying or acting on any material contained in or suggested by this Practice.

Use of trade names should not be viewed as an expression of preference. Other brands having the same specifications are equally correct and may be substituted for those named.

This Practice is subject to revision at any time. For more information refer to PIP ADG001, *Specification for Developing Practices*.

© 2004 Process Industry Practices (PIP), Construction Industry Institute, and The University of Texas at Austin on behalf of the Board of Regents of the University of Texas System

Process Industry Practices  
3925 West Braker Lane (R4500)  
Austin, Texas 78759

### **PUBLISHING HISTORY**

December 2004 *Issued*  
January 2016 *Complete Revision*  
December 2023 *Technical Revision*

Not printed with State funds



# PIP PCCA001

## Fixed Gas Detection Design Criteria

---

### Table of Contents

- 1. Scope ..... 2**
- 2. References ..... 2**
  - 2.1 Process Industry Practices.....2
  - 2.2 Industry Codes and Standards.....2
- 3. Definitions ..... 2**
- 4. Requirements ..... 3**
  - 4.1 General Design.....3
  - 4.2 Types of Combustible Gas Detectors.....4
  - 4.3 Oxygen and Toxic Gas Detectors .....5
  - 4.4 Detector Location .....5
  - 4.5 Environmental Considerations .....5
  - 4.6 Calibration and Testing .....6
  - 4.7 Detector Electronics .....6

### Data Form

PIP PCCA001-D – Fixed Gas Detector Data Sheet

## 1. Scope

---

This Practice provides design criteria for fixed gas detectors installed in process areas to detect the presence of combustible, oxygen, or toxic gases. This Practice addresses combustible, oxygen, and toxic gas detectors permanently installed for ambient air monitoring (e.g., leak detection, oxygen depletion). The technologies included are catalytic bead, infrared, and electrochemical.

This Practice does not cover portable gas monitoring equipment, process analyzers, or sampling systems. The systems used to perform data acquisition, alarming, and control action are not covered by this Practice because the solutions are diverse and can include stand-alone to advanced multisystem configurations.

## 2. References

---

Applicable parts of the following Practices and industry codes and standards shall be considered an integral part of this Practice. The edition in effect on the date of contract award shall be used, except as otherwise noted. Short titles are used herein where appropriate.

### 2.1 Process Industry Practices (PIP)

- PIP PCCA001-D - *Fixed Gas Detector Data Sheet* (included with this Practice)
- PIP PCEA001 - *Fixed Gas Detection Guidelines*

### 2.2 Industry Codes and Standards

- The Instrumentation International Society of Automation (ISA)
  - ANSI/ISA 92.00.01 - *Performance Requirements for Toxic Gas Detectors*
  - ANSI/ISA 92.00.02 - *Installation, Operation, and Maintenance of Toxic Gas Instruments*

## 3. Definitions

---

CSA: Canadian Standards Association

*fixed gas detector*: An integral device that consists of a sensor to sense the target gas, electronics to determine the concentration and provide analog, digital, and/or discrete outputs, and may have a local display

FM: Factory Mutual

LEL: Lower explosive limit, which is the minimum concentration of a gas in a gas/air mixture at which the mixture will explode if exposed to an ignition source

NRTL: Nationally Recognized Testing Laboratories

owner: Party who owns the facility wherein fixed gas detection will be used

UL: Underwriters Laboratory