



PROCESS
INDUSTRY
PRACTICES

COMPLETE REVISION
December 2021

Process Control

PIP PCEIA001
Instrument Air Systems Guideline

PURPOSE AND USE OF PROCESS INDUSTRY PRACTICES

In an effort to minimize the cost of process industry facilities, this Practice has been prepared from the technical requirements in the existing standards of major industrial users, contractors, or standards organizations. By harmonizing these technical requirements into a single set of Practices, administrative, application, and engineering costs to both the purchaser and the manufacturer should be reduced. While this Practice is expected to incorporate the majority of requirements of most users, individual applications may involve requirements that will be appended to and take precedence over this Practice. Determinations concerning fitness for purpose and particular matters or application of the Practice to particular project or engineering situations should not be made solely on information contained in these materials. The use of trade names from time to time should not be viewed as an expression of preference but rather recognized as normal usage in the trade. Other brands having the same specifications are equally correct and may be substituted for those named. All Practices or guidelines are intended to be consistent with applicable laws and regulations including OSHA requirements. To the extent these Practices or guidelines should conflict with OSHA or other applicable laws or regulations, such laws or regulations must be followed. Consult an appropriate professional before applying or acting on any material contained in or suggested by the Practice.

This Practice is subject to revision at any time.

© Process Industry Practices (PIP), Construction Industry Institute, The University of Texas at Austin, 3925 West Braker Lane (R4500), Austin, Texas 78759. PIP Member Companies and Subscribers may copy this Practice for their internal use. Changes or modifications of any kind are not permitted within any PIP Practice without the express written authorization of PIP. Authorized Users may attach addenda or overlays to clearly indicate modifications or exceptions to specific sections of PIP Practices. Authorized Users may provide their clients, suppliers and contractors with copies of the Practice solely for Authorized Users' purposes. These purposes include but are not limited to the procurement process (e.g., as attachments to requests for quotation/ purchase orders or requests for proposals/contracts) and preparation and issue of design engineering deliverables for use on a specific project by Authorized User's client. PIP's copyright notices must be clearly indicated and unequivocally incorporated in documents where an Authorized User desires to provide any third party with copies of the Practice.

PUBLISHING HISTORY

<i>October 1997</i>	<i>Issued</i>	<i>July 2016</i>	<i>Complete Revision</i>
<i>June 2003</i>	<i>Editorial Revision</i>	<i>December 2021</i>	<i>Complete Revision</i>
<i>July 2011</i>	<i>Complete Revision</i>		

Not printed with State funds



PIP PCEIA001 Instrument Air Systems Guideline

Table of Contents

1. Scope	2	5.2 Design Considerations	7
2. References	2	5.3 Inert Gas Backup Supply	8
2.1 Process Industry Practices	2	6. Piping Distribution System	8
2.2 Industry Codes and Standards	2	6.1 General.....	8
3. System Design	2	6.2 Piping and Tubing	9
3.1 General	2	6.3 Valves.....	9
3.2 System Pressure	3	7. Testing - Piping	10
3.3 Capacity/Sizing	3		
3.4 Air Quality	3		
3.5 Air-sets	4		
4. Equipment	4		
4.1 General	4		
4.2 Monitoring and Control Systems	4		
4.3 Compressors	5		
4.4 Intake Air Filters.....	5		
4.5 Compressor Aftercoolers.....	5		
4.6 Air Receivers	5		
4.7 Air Dryers.....	6		
4.8 Air Dryer Prefilters	6		
4.9 Afterfilters	7		
5. Reliability and Availability.....	7		
5.1 General	7		

1. Scope

This Practice provides guidelines for designing instrument air systems that supply pneumatically actuated instruments and valves. This Practice provides design guidelines for air quality, capacity, sizing, and testing of instrument air systems.

2. References

Applicable parts of the following Practices and industry codes and standards shall be considered an integral part of this Practice. The edition in effect on the date of contract award shall be used, except as otherwise noted. Short titles are used herein where appropriate.

2.1 Process Industry Practices (PIP)

- PIP PCCIA001 - *Instrument Air Systems Design Criteria*
- PIP PCCIP001 - *Instrument Piping and Tubing Systems Criteria*
- PIP PCIIA000 - *Instrument Air Installation Details*

2.2 Industry Codes and Standards

- American Petroleum Institute (API)
 - API STD 672 - *Packaged, Integrally Geared Centrifugal Air Compressors for Petroleum, Chemical, and Gas Industry Services*
- American Society for Mechanical Engineers (ASME)
 - ASME - *Boiler and Pressure Vessel Code*, Section VIII, Division 1
- (ISA) The International Society of Automation
 - ISA 7.0.01 - *Quality Standard for Instrument Air*
- National Fire Protection Association (NFPA)
 - NFPA 496 - *Standard for Purged and Pressurized Enclosures for Electrical Equipment*

3. System Design

3.1 General

- 3.1.1 The instrument air system should be designed to meet the specified pressure, capacity, and air quality requirements.
- 3.1.2 The instrument air system should not be cross-connected to any other air system other than the backup system to prevent cross-contamination.
- 3.1.3 Instrument air should only be used for pneumatic instrumentation, and for purging instrumentation enclosures in accordance with *NFPA 496*.

3.1.4 Purging Process Connections

- 3.1.4.1 Provisions should be made to prevent the backflow of process material to the instrument air system from process connections.
- 3.1.4.2 Instrument air should not be used for processes that cannot have air or require an inert gas.