



PROCESS
INDUSTRY
PRACTICES

November 2022

Electrical

**PIP ELEGL09
Electrical Power System
Event Reporting Guideline**

PURPOSE AND USE OF PROCESS INDUSTRY PRACTICES

In an effort to minimize the cost of process industry facilities, this Practice has been prepared from the technical requirements in the existing standards of major industrial users, contractors, or standards organizations. By harmonizing these technical requirements into a single set of Practices, administrative, application, and engineering costs to both the purchaser and the manufacturer should be reduced. While this Practice is expected to incorporate the majority of requirements of most users, individual applications may involve requirements that will be appended to and take precedence over this Practice. Determinations concerning fitness for purpose and particular matters or application of the Practice to particular project or engineering situations should not be made solely on information contained in these materials. The use of trade names from time to time should not be viewed as an expression of preference but rather recognized as normal usage in the trade. Other brands having the same specifications are equally correct and may be substituted for those named. All Practices or guidelines are intended to be consistent with applicable laws and regulations including OSHA requirements. To the extent these Practices or guidelines should conflict with OSHA or other applicable laws or regulations, such laws or regulations must be followed. Consult an appropriate professional before applying or acting on any material contained in or suggested by the Practice.

This Practice is subject to revision at any time.

© Process Industry Practices (PIP), Construction Industry Institute, The University of Texas at Austin, 3925 West Braker Lane (R4500), Austin, Texas 78759. PIP Member Companies and Subscribers may copy this Practice for their internal use. Changes or modifications of any kind are not permitted within any PIP Practice without the express written authorization of PIP. Authorized Users may attach addenda or overlays to clearly indicate modifications or exceptions to specific sections of PIP Practices. Authorized Users may provide their clients, suppliers and contractors with copies of the Practice solely for Authorized Users' purposes. These purposes include but are not limited to the procurement process (e.g., as attachments to requests for quotation/purchase orders or requests for proposals/contracts) and preparation and issue of design engineering deliverables for use on a specific project by Authorized User's client. PIP's copyright notices must be clearly indicated and unequivocally incorporated in documents where an Authorized User desires to provide any third party with copies of the Practice.

PUBLISHING HISTORY

November 2022 Issued

Not printed with State funds



PIP ELEGL09 Electrical Power System Event Reporting Guideline

Table of Contents

- 1. Scope 2**
- 2. References 2**
 - 2.1 Process Industry Practices 2
 - 2.2 Industry Codes, Standards, and Publications 2
- 3. Definitions 3**
- 4. Metrics 5**
 - 4.1 Utility Based Metrics 5
 - 4.2 Process Industry Based Metrics 6
 - 4.3 Data Requirements to Produce Performance Metrics 11
 - 4.4 Data Collection 12
 - 4.5 Data Analysis and Reporting 14

Appendix C – Equipment Element Data Collection Form

Appendix D – Example of an Electrical Power System for the Process Industry

Appendix E – An Example of Data Collection, Calculated Metrics, Reporting, and Analysis for a Process Industry Electrical Power System

Data Form
ELEGS01-F – Grounding Calculations

Appendix A – Calculating MTBF When Zero Outages / Interruptions

Appendix B – Electrical Event Reporting Form

1. Scope

This Practice addresses the reporting and analyzing of electrical events associated with the electrical power delivery system(s) for process industries. These events can affect the dependability of the electrical system. Adverse electrical system events can cause safety, environmental, and economic impact to employees, surrounding communities, and businesses. Understanding the relationship between electrical system dependability and the adverse impact due to events can help to improve the electrical power delivery system.

Methods to calculate the effect of electrical events associated with the electrical power delivery system(s) for process industries are described within this Practice. The means to collect, store, calculate, and report data from electrical events can be by means of commercial software or maintenance management software as chosen by the owner.

Existing utility-based metrics for both distribution and transmission systems will be reviewed as to their applicability for use in the process industry environment.

Reporting and analyzing events associated with electrical utilization equipment, e.g., electric motors, lighting, HVAC, etc., is outside the scope of this Practice. Electrical events associated with utilization equipment should, however, be reported and analyzed through the owner's maintenance management system.

2. References

Applicable parts of the following Practices, industry codes and standards, and publications shall be considered an integral part of this Practice. The edition in effect on the date of contract award shall be used, except as otherwise noted. Short titles are used herein where appropriate.

2.1 Process Industry Practices (PIP)

- PIP ELEGL09-F1 – *Electrical Power System Reliability Metric Calculator* (included in this Practice)

2.2 Industry Codes, Standards, and Publications

- CIGRE
 - [1] *Methodology for Reliability Analysis of Power Transformers Based on Failure Data – The 20th International Symposium on High Voltage Engineering, ISH 2017-367*
- Electrical Power Research Institute (EPRI)
 - [2] *Reliability of Electric Utility Distribution Systems: EPRI White Paper (Final Report, October 2000)*
- Institute of Electrical and Electronic Engineers (IEEE)
 - [3] IEEE 100 – *The Authoritative Dictionary of IEEE Standards Terms, Seventh Edition*
 - IEEE Std 493 – *IEEE Recommended Practice for the Design of Reliable Industrial and Commercial Power Systems*