

AS 16890.2:2024



Air filters for general ventilation

Part 2: Measurement of fractional efficiency and air flow resistance (ISO 16890-2:2022, MOD)



AS 16890.2:2024

This Australian Standard ® was prepared by ME-080, Air Filters. It was approved on behalf of Standards Australia's Standards Development and Accreditation Committee on 21 October 2024.

This Standard was published on 1 November 2024.

The following are represented on Committee ME-080:

Air Conditioning & Mechanical Contractors Association of Australia
Australian Institute of Refrigeration Air Conditioning and Heating
AWTA Product Testing (Testing Interests Australia)
Chartered Institution of Building Services Engineers
Consumer Electronics Suppliers Association
CSIRO
Engineers Australia
Facility Management Association of Australia
Institute of Healthcare Engineering Australia
Medical Technology Association of Australia
National Association of Testing Authorities Australia

This Standard was issued in draft form for comment as DR AS 16890.2:2023.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

ISBN 978 1 76139 895 7

Air filters for general ventilation

Part 2: Measurement of fractional efficiency and air flow resistance (ISO 16890-2:2022, MOD)

Originated as part of AS 1323—1973 and AS 1324—1973.
Revised and redesignated as AS 1324.1—1996 and AS 1324.2—1996.
Previous editions AS 1324.1—2001 and AS 1324.2—2003.
Revised in part and redesignated as AS 16890.2:2024.

COPYRIGHT

© ISO 2024 — All rights reserved
© Standards Australia Limited 2024

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth).

Preface

This Standard was prepared by the Standards Australia Committee ME-080, Air Filters, to supersede AS 1324.1—2001, *Air filters for use in general ventilation and airconditioning, Part 1: Application, performance, and construction* and AS 1324.2—2003, *Air filters for use in general ventilation and airconditioning, Part 2: Methods of test*.

AS 1324.1—2001 and AS 1324.2—2003 will remain current for 2 years after the date of publication of this document. After this time, they will be superseded by AS 16890.2:2024. Regulatory authorities that reference this document in regulation may apply these requirements at a different time. Users of this document should consult with these authorities to confirm their requirements.

The objective of this document is to specify the aerosol production, the test equipment and the test methods used for measuring fractional efficiency and air flow resistance of air filters for general ventilation. It is intended for use in conjunction with AS 16890.1:2024, AS 16890.3:2024 and AS 16890.4:2024.

A list of all parts in the AS 16890 series can be found in the [Standards Australia online catalogue](#).

This document is an adoption with national modifications and has been reproduced from ISO 16890-2:2022, *Air filters for general ventilation — Part 2: Measurement of fractional efficiency and air flow resistance*. The modifications are additional requirements and are set out in [Appendix ZZ](#), which has been added at the end of the source text.

[Appendix ZZ](#) lists the modifications to ISO 16890-2:2022 for the application of this document in Australia.

As this document has been reproduced from an International document, a full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

Contents

| | |
|---|-----------|
| Preface | ii |
| Foreword | vi |
| Introduction | viii |
| 1 Scope | 1 |
| 2 Normative references | 1 |
| 3 Terms and definitions | 1 |
| 3.1 Air flow and resistance | 1 |
| 3.2 Test device | 2 |
| 3.3 Aerosol | 2 |
| 3.4 Particle counter | 3 |
| 3.5 Efficiency | 3 |
| 3.6 Other terms | 4 |
| 4 Symbols and abbreviated terms | 4 |
| 4.1 Symbols | 4 |
| 4.2 Abbreviated terms | 6 |
| 5 General test requirements | 6 |
| 5.1 Test device requirements | 6 |
| 5.2 Test device installation | 6 |
| 5.3 Test rig requirements | 6 |
| 6 Test materials | 7 |
| 6.1 Liquid phase aerosol | 7 |
| 6.1.1 DiEthylHexylSebacate (DEHS) test aerosol | 7 |
| 6.1.2 DEHS properties | 7 |
| 6.1.3 Liquid phase aerosol generation | 7 |
| 6.2 Solid phase aerosol | 8 |
| 6.2.1 Potassium chloride (KCl) test aerosol | 8 |
| 6.2.2 KCl properties | 8 |
| 6.2.3 Solid phase aerosol generation | 9 |
| 6.3 Reference aerosols | 10 |
| 6.3.1 Reference aerosol for 0,3 µm to 1,0 µm | 10 |
| 6.3.2 Reference aerosol for 1,0 µm to 10,0 µm | 10 |
| 6.4 Aerosol loading | 10 |
| 7 Test equipment | 11 |
| 7.1 Test rig | 11 |
| 7.1.1 Dimensions | 11 |
| 7.1.2 Construction materials | 11 |
| 7.1.3 Test rig shape | 12 |
| 7.1.4 Test rig air supply | 12 |
| 7.1.5 Test rig isolation | 12 |
| 7.1.6 D/S mixing orifice | 12 |
| 7.1.7 Aerosol sampling | 13 |
| 7.1.8 Test rig air flow rate measurement | 15 |
| 7.1.9 Resistance to air flow measurement | 15 |
| 7.1.10 Test devices not measuring 610 mm × 610 mm (24.0 inches × 24.0 inches) | 16 |
| 7.1.11 Dust injection testing | 16 |
| 7.2 Aerosol particle counter | 17 |
| 7.2.1 General | 17 |
| 7.2.2 OPC sampled size range | 17 |
| 7.2.3 OPC particle size ranges | 17 |
| 7.2.4 Sizing resolution | 18 |
| 7.2.5 Calibration | 18 |

| | | |
|-----------|--|-----------|
| 7.2.6 | Air flow rate..... | 18 |
| 7.2.7 | Zero counting..... | 18 |
| 7.2.8 | Dual OPC(s)..... | 18 |
| 7.3 | Temperature, relative humidity..... | 18 |
| 8 | Qualification of test rig and apparatus..... | 19 |
| 8.1 | Schedule of qualification testing requirements..... | 19 |
| 8.1.1 | General..... | 19 |
| 8.1.2 | Qualification testing..... | 19 |
| 8.1.3 | Qualification documentation..... | 19 |
| 8.2 | Qualification testing..... | 20 |
| 8.2.1 | Test rig — Pressure system testing..... | 20 |
| 8.2.2 | OPC — Air flow rate stability test..... | 21 |
| 8.2.3 | OPC — Zero test..... | 21 |
| 8.2.4 | OPC — Sizing accuracy..... | 21 |
| 8.2.5 | OPC — Overload test..... | 22 |
| 8.2.6 | Aerosol generator — Response time..... | 22 |
| 8.2.7 | Aerosol generator — Neutralizer..... | 23 |
| 8.2.8 | Test rig — Air leakage test..... | 24 |
| 8.2.9 | Test rig — Air velocity uniformity..... | 24 |
| 8.2.10 | Test rig — Aerosol uniformity..... | 25 |
| 8.2.11 | Test rig — Downstream mixing..... | 26 |
| 8.2.12 | Test rig — Empty test device section pressure..... | 28 |
| 8.2.13 | Test rig — 100 % efficiency test and purge time..... | 28 |
| 8.2.14 | Test rig — Correlation ratio..... | 29 |
| 8.3 | Maintenance..... | 29 |
| 8.3.1 | General..... | 29 |
| 8.3.2 | Test rig — Background counts..... | 30 |
| 8.3.3 | Test rig — Reference filter test..... | 30 |
| 8.3.4 | Test rig — Pressure reference test..... | 31 |
| 8.3.5 | Test rig — Final filter resistance..... | 32 |
| 9 | Test methods..... | 32 |
| 9.1 | Air flow rate..... | 32 |
| 9.2 | Measurement of resistance to air flow..... | 32 |
| 9.3 | Measurement of fractional efficiency..... | 32 |
| 9.3.1 | Aerosol sampling protocol..... | 32 |
| 9.3.2 | Background sampling..... | 32 |
| 9.3.3 | Testing sequence for a single OPC..... | 33 |
| 9.3.4 | Testing sequence for dual OPC..... | 37 |
| 10 | Data reduction and calculations..... | 38 |
| 10.1 | Correlation ratio..... | 38 |
| 10.1.1 | Correlation ratio general..... | 38 |
| 10.1.2 | Correlation ratio data reduction..... | 39 |
| 10.2 | Penetration and fractional efficiency..... | 41 |
| 10.2.1 | Penetration and fractional efficiency general..... | 41 |
| 10.2.2 | Penetration data reduction..... | 41 |
| 10.3 | Data quality requirements..... | 43 |
| 10.3.1 | Correlation background counts..... | 43 |
| 10.3.2 | Efficiency background counts..... | 44 |
| 10.3.3 | Correlation ratio..... | 44 |
| 10.3.4 | Penetration..... | 44 |
| 10.4 | Fractional efficiency calculation..... | 45 |
| 11 | Reporting results..... | 45 |
| 11.1 | General..... | 45 |
| 11.2 | Required reporting elements..... | 46 |
| 11.2.1 | Report general..... | 46 |
| 11.2.2 | Report values..... | 46 |

| | | |
|---------------------|--|-----------|
| 11.2.3 | Report summary | 46 |
| 11.2.4 | Report details | 47 |
| Annex A | (informative) Example | 51 |
| Annex B | (informative) Resistance to air flow calculation | 59 |
| Bibliography | | 61 |
| Appendix ZZ | (normative) Modifications to ISO 16890-2:2022 for Australia | 62 |

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

The procedures used to develop this document and those intended for its further maintenance are described in the ISO/IEC Directives, Part 1. In particular, the different approval criteria needed for the different types of ISO documents should be noted. This document was drafted in accordance with the editorial rules of the ISO/IEC Directives, Part 2 (see www.iso.org/directives).

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights. Details of any patent rights identified during the development of the document will be in the Introduction and/or on the ISO list of patent declarations received (see www.iso.org/patents).

Any trade name used in this document is information given for the convenience of users and does not constitute an endorsement.

For an explanation of the voluntary nature of standards, the meaning of ISO specific terms and expressions related to conformity assessment, as well as information about ISO's adherence to the World Trade Organization (WTO) principles in the Technical Barriers to Trade (TBT), see www.iso.org/iso/foreword.html.

This document was prepared by Technical Committee ISO/TC 142, *Cleaning equipment for air and other gases*, in collaboration with the European Committee for Standardization (CEN) Technical Committee CEN/TC 195, *Cleaning equipment for air and other gases*, in accordance with the Agreement on technical cooperation between ISO and CEN (Vienna Agreement).

This second edition cancels and replaces the first edition (ISO 16890-2:2016), which has been technically revised.

The main changes are as follows:

- definition of light scattering airborne particle counter (LSAPC) has been added in [Clause 3](#);
- rewording of [6.3.1](#) and removal of 6.3.3 and 6.3.4 eliminating the matching criteria and use of alternate aerosols;
- in [Figure 3](#), the distance between pressure drop taps and test device (7-8), wrongly indicated as 350 mm has been modified with “≥350 mm”;
- in [7.1.6](#) and [8.3.3.4](#), a sentence has been added to specify that the D/S mixing orifice shall not be installed during resistance to airflow measurement;
- in [7.2.1](#), aerosol particle counters (APC) and light scattering aerosol particle counter (LSAPC) have been added as common examples of aerosol particle counter;
- in [7.2.5](#), the incorrect reference to ISO 21501-4 has been corrected with ISO 21501-1;
- in [10.3.2](#), “correlation” has been changed to “efficiency” to be consistent with the title of the subclause;
- in [11.2.3](#), c), 6), iv), the word “additive” has been changed to “adhesive” to be consistent with the template of [Table 10](#);

- the example of the test report in Figure A.1 has been updated to match the template report of [Table A.10](#).

A list of all parts in the ISO 16890 series can be found on the ISO website.

Any feedback or questions on this document should be directed to the user's national standards body. A complete listing of these bodies can be found at www.iso.org/members.html.

Introduction

The effects of particulate matter (PM) on human health have been extensively studied in the past decades. The results are that fine dust can be a serious health hazard, contributing to or even causing respiratory and cardiovascular diseases. Different classes of PM can be defined according to the particle size range. The most important ones are PM₁₀, PM_{2,5} and PM₁. The United States Environmental Protection Agency (EPA), the World Health Organization (WHO) and the European Union define PM₁₀ as PM which passes through a size-selective inlet with a 50 % efficiency cut-off at 10 µm aerodynamic diameter. PM_{2,5} and PM₁ are similarly defined. However, this definition is not precise if there is no further characterization of the sampling method and the sampling inlet with a clearly defined separation curve. In Europe, the reference method for the sampling and measurement of PM₁₀ is described in EN 12341. The measurement principle is based on the collection on a filter of the PM₁₀ fraction of ambient PM and the gravimetric mass determination (see Reference [10]).

As the precise definition of PM₁₀, PM_{2,5} and PM₁ is quite complex and not easy to measure, public authorities, such as the US EPA or the German Federal Environmental Agency (Umweltbundesamt), increasingly use in their publications the simpler denotation of PM₁₀ as being the particle size fraction less or equal to 10 µm. Since this deviation to the above-mentioned complex “official” definition does not have a significant impact on a filter element’s particle removal efficiency, the ISO 16890 series refers to this simplified definition of PM₁₀, PM_{2,5} and PM₁.

PM in the context of the ISO 16890 series describes a size fraction of the natural aerosol (liquid and solid particles) suspended in ambient air. The symbol ePM_x describes the efficiency of an air cleaning device to particles with an optical diameter between 0,3 µm and x µm. The following particle size ranges are used in the ISO 16890 series for the listed efficiency values as shown in [Table 1](#).

Table 1 — Optical particle diameter size ranges for the definition of the efficiencies, ePM_x

| Efficiency | Size range, µm |
|-------------|-----------------------|
| ePM_{10} | $0,3 \leq x \leq 10$ |
| $ePM_{2,5}$ | $0,3 \leq x \leq 2,5$ |
| ePM_1 | $0,3 \leq x \leq 1$ |

Air filters for general ventilation are widely used in heating, ventilation and air-conditioning applications of buildings. In this application, air filters significantly influence the indoor air quality and, hence, the health of people, by reducing the concentration of PM. To enable design engineers and maintenance personnel to choose the correct filter types, there is an interest from international trade and manufacturing for a well-defined, common method of testing and classifying air filters according to their particle efficiencies, especially with respect to the removal of PM. Current regional standards are applying completely different testing and classification methods, which do not allow any comparison with each other, and thus hinder global trade with common products. Additionally, the current industry standards have known limitations by generating results which often are far away from filter performance in service, i.e. overstating the particle removal efficiency of many products. With the ISO 16890 series, a completely new approach for a classification system is adopted, which gives better and more meaningful results compared to the existing standards.

The ISO 16890 series describes the equipment, materials, technical specifications, requirements, qualifications and procedures to produce the laboratory performance data and efficiency classification based upon the measured fractional efficiency converted into a particulate matter efficiency (ePM) reporting system.

Air filter elements according to the ISO 16890 series are evaluated in the laboratory by their ability to remove aerosol particulate expressed as the efficiency values ePM_1 , $ePM_{2,5}$ and ePM_{10} . The air filter elements can then be classified according to the procedures defined in ISO 16890-1. The particulate removal efficiency of the filter element is measured as a function of the particle size in the range of 0,3 µm to 10 µm of the unloaded and unconditioned filter element as per the procedures defined in this document. After the initial particulate removal efficiency testing, the air filter element is conditioned according to the procedures defined in ISO 16890-4 and the particulate removal efficiency is repeated

on the conditioned filter element. This is done to provide information about the intensity of any electrostatic removal mechanism which can possibly be present with the filter element for test. The average efficiency of the filter is determined by calculating the mean between the initial efficiency and the conditioned efficiency for each size range. The average efficiency is used to calculate the ePM_x efficiencies by weighting these values to the standardized and normalized particle size distribution of the related ambient aerosol fraction. When comparing filters tested in accordance with the ISO 16890 series, the fractional efficiency values are always compared among the same ePM_x class (e.g. ePM_1 of filter A with ePM_1 of filter B). The test dust capacity and the initial arrestance of a filter element are determined as per the test procedures defined in ISO 16890-3.

The results from this document can also be used by other standards that define or classify the fractional efficiency in the size range of 0,3 μm to 10 μm when electrostatic removal mechanism is an important factor to consider, for example ISO 29461.

The performance results obtained in accordance with the ISO 16890 series cannot by themselves be quantitatively applied to predict performance in service with regard to efficiency and lifetime.

NOTES

Australian Standard®

Air filters for general ventilation

Part 2: Measurement of fractional efficiency and air flow resistance (ISO 16890-2:2022, MOD)

1 Scope

This document specifies the aerosol production, the test equipment and the test methods used for measuring fractional efficiency and air flow resistance of air filters for general ventilation.

It is intended to be used in conjunction with ISO 16890-1, ISO 16890-3 and ISO 16890-4.

The test method described in this document is applicable for air flow rates between 0,25 m³/s (900 m³/h, 530 ft³/min) and 1,5 m³/s (5 400 m³/h, 3 178 ft³/min), referring to a test rig with a nominal face area of 610 mm × 610 mm (24.0 inches × 24.0 inches).

This document refers to particulate air filter elements for general ventilation having an ePM₁ efficiency less than or equal to 99 % and an ePM₁₀ efficiency greater than 20 % when tested as per the procedures defined within the ISO 16890 series.

NOTE The lower limit for this test procedure is set at a minimum ePM₁₀ efficiency of 20 % since it is very difficult for a test filter element below this level to meet the statistical validity requirements of this procedure.

This document is not applicable to filter elements used in portable room-air cleaners.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

ISO 5167-1, *Measurement of fluid flow by means of pressure differential devices inserted in circular cross-section conduits running full — Part 1: General principles and requirements*

ISO 21501-1, *Determination of particle size distribution — Single particle light interaction methods — Part 1: Light scattering aerosol spectrometer*

ISO 29463-1, *High efficiency filters and filter media for removing particles from air — Part 1: Classification, performance, testing and marking*

3 Terms and definitions

For the purposes of this document the following terms and definitions apply.

ISO and IEC maintain terminology databases for use in standardization at the following addresses:

- ISO Online browsing platform: available at <https://www.iso.org/obp>
- IEC Electropedia: available at <https://www.electropedia.org/>

3.1 Air flow and resistance

3.1.1

air flow rate

volume of air flowing through the filter per unit time

[SOURCE: ISO 29464:2017, 3.1.24]