



CGA E-15—2017

REAFFIRMED 2023

GUIDELINE FOR PERIODIC SERVICE PROGRAM FOR INDUSTRIAL GAS REGULATORS

THIRD EDITION

PLEASE NOTE:

The information contained in this document was obtained from sources believed to be reliable and is based on technical information and experience currently available from members of the Compressed Gas Association, Inc. and others. However, the Association or its members, jointly or severally, make no guarantee of the results and assume no liability or responsibility in connection with the information or suggestions herein contained. Moreover, it should not be assumed that every acceptable commodity grade, test or safety procedure or method, precaution, equipment or device is contained within, or that abnormal or unusual circumstances may not warrant or suggest further requirements or additional procedure.

This document is subject to periodic review, and users are cautioned to obtain the latest edition. The Association invites comments and suggestions for consideration. In connection with such review, any such comments or suggestions will be fully reviewed by the Association after giving the party, upon request, a reasonable opportunity to be heard. Proposed changes may be submitted via the Internet at our web site, www.cganet.com.

This document should not be confused with federal, state, provincial, or municipal specifications or regulations; insurance requirements; or national safety codes. While the Association recommends reference to or use of this document by government agencies and others, this document is purely voluntary and not binding unless adopted by reference in regulations.

A listing of all publications, audiovisual programs, safety and technical bulletins, and safety posters is available via the Internet at our website at www.cganet.com. For more information contact CGA at Phone: 703-788-2700, ext. 799. E-mail: customerservice@cganet.com.

Work Item 22-023
Industrial Gases Apparatus Committee

NOTE—Technical changes from the previous edition are underlined.

NOTE—No technical information has been changed from the 2017 edition. This reaffirmed edition may include minor editorial changes.

REAFFIRMED 2023
THIRD EDITION: 2017
SECOND EDITION: 2011
FIRST EDITION: 2005

© 2017 The Compressed Gas Association, Inc. All rights reserved.

All materials contained in this work are protected by United States and international copyright laws. No part of this work may be reproduced or transmitted in any form or by any means, electronic or mechanical including photocopying, recording, or any information storage and retrieval system without permission in writing from The Compressed Gas Association, Inc. All requests for permission to reproduce material from this work should be directed to The Compressed Gas Association, Inc., 8484 Westpark Drive, Suite 220, McLean, VA 22102. You may not alter or remove any trademark, copyright or other notice from this work.

Contents	Page
1 Introduction.....	1
2 Scope	1
3 Definitions.....	1
4 Manufacturer’s instructions	2
5 Instructions for the end user.....	2
6 Instructions for servicing regulators.....	3
7 Service tags.....	3
7.1 Specifications	3
7.2 Markings	3
7.3 Location	5
8 References	5

Figures

Figure 1—Example of service due date location (showing backside of regulator).....	2
Figure 2—Recommended service tag size specifications.....	3
Figure 3—Front side of service tag	4
Figure 4—Back side of service tag	4

1 Introduction

Regulators have a finite service life that is a function of several variables, and consequently, they require regular inspection and periodic maintenance to be kept in service.

Materials used in regulators, particularly elastomeric or rubber materials, will deteriorate over time. Aged elastomeric materials can exhibit hardening, stress cracking, and other physical property degradation. Regulator components such as diaphragms, relief valves, seat assemblies, and gauges can be dramatically affected by material aging.

When regulators are manufactured, they should meet strict industry standards for cleanliness. Over time, regulators can become contaminated with dust, grease, and organic substances. Because oxygen can react violently with these substances, this contamination can be dangerous since it increases the potential for oxygen fires. Particles can be generated from continual connecting and disconnecting to and from cylinder valve. Particulates can lead to particle impact, which in the presence of high pressure oxygen increases the potential for oxygen fires. Contamination and/or particulates can also cause internal components to fail or malfunction, which can lead to leakage of flammable, asphyxiant, or other hazardous gases from the regulator and/or parts being expelled from the regulator.

It is not uncommon to see regulators for sale at flea markets, garage sales, auctions, e-commerce, or other places where used industrial equipment can be bought and sold. Typically, these regulators have not been properly maintained, creating a variety of safety hazards for the user. If the service history of a previously used industrial regulator that is acquired is unknown, then it is strongly suggested that it not be placed into service. Because the general public is often unaware of the potential danger(s) of using old, ill-repaired, or contaminated regulators, incidents involving these regulators have resulted in serious injuries and deaths.

2 Scope

This publication establishes a program for marking a service date on compressed gas regulators intended for use in welding, cutting, and allied processes. It also informs end users and the regulator service repair industry of actions they should take to properly mark and maintain regulators. This program can be applied to regulators used in other applications such as specialty gas, etc.

Customer-specified regulators, original equipment manufacturer (OEM), and special application regulators may be excluded as agreed upon by the manufacturer and the customer.

3 Definitions

For the purpose of this publication, the following definitions apply.

3.1 Publication terminology

3.1.1 Shall

Indicates that the procedure is mandatory. It is used wherever the criterion for conformance to specific recommendations allows no deviation.

3.1.2 Should

Indicates that a procedure is recommended.

3.1.3 May

Indicates that the procedure is optional.

3.1.4 Will

Is used only to indicate the future, not a degree of requirement.

3.1.5 Can

Indicates a possibility or ability.