



Approved Method: **Life Testing of  
High Intensity Discharge  
(HID) Lamps**

**IES APPROVED METHOD  
FOR LIFE TESTING OF  
HIGH INTENSITY DISCHARGE (HID) LAMPS**

Publication of this report  
has been approved by IES.  
Suggestions for revisions  
should be directed to IES.

**Prepared by:  
The Photometry of Light Sources Subcommittee  
of the IES Testing Procedures Committee**

*Copyright 2012 by the Illuminating Engineering Society of North America.*

*Approved by the IES Board of Directors January 9, 2012, as a Transaction of the Illuminating Engineering Society of North America.*

*All rights reserved. No part of this publication may be reproduced in any form, in any electronic retrieval system or otherwise, without prior written permission of the IES.*

Published by the Illuminating Engineering Society of North America, 120 Wall Street, New York, New York 10005.

IES Standards and Guides are developed through committee consensus and produced by the IES Office in New York. Careful attention is given to style and accuracy. If any errors are noted in this document, please forward them to Rita Harrold, Director of Technology, at the above address for verification and correction. The IES welcomes and urges feedback and comments.

ISBN # 978-0-87995-265-5

*Printed in the United States of America.*

#### **DISCLAIMER**

IES publications are developed through the consensus standards development process approved by the American National Standards Institute. This process brings together volunteers representing varied viewpoints and interests to achieve consensus on lighting recommendations. While the IES administers the process and establishes policies and procedures to promote fairness in the development of consensus, it makes no guaranty or warranty as to the accuracy or completeness of any information published herein.

The IES disclaims liability for any injury to persons or property or other damages of any nature whatsoever, whether special, indirect, consequential or compensatory, directly or indirectly resulting from the publication, use of, or reliance on this document

In issuing and making this document available, the IES is not undertaking to render professional or other services for or on behalf of any person or entity. Nor is the IES undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances.

The IES has no power, nor does it undertake, to police or enforce compliance with the contents of this document. Nor does the IES list, certify, test or inspect products, designs, or installations for compliance with this document. Any certification or statement of compliance with the requirements of this document shall not be attributable to the IES and is solely the responsibility of the certifier or maker of the statement.

**Prepared by the Subcommittee on Photometry of Light Sources of the  
Testing Procedures Committee**

**Photometry of Light Sources Subcommittee**

**Mark Sapcoe, Chair**  
**Greg McKee, Chair**

Lawrence Ayers\*  
Rolf Bergman  
Eric Bretschneider\*  
David Chan\*  
Ronald Daubach\*  
Steven Eilersick\*  
David Ellis

Po-Chieh Hung\*  
Andrew Jackson  
Demetrios Karambelas  
Mihaly Kotrebai  
Kevin Krueger  
James Leland\*  
Joseph Linquata\*

Robert Low\*  
Joseph Marella  
C. Cameron Miller  
Francois-Xavier Morin\*  
Yoshihiro Ohno

**Testing Procedures Committee**

**Michael Grather, Chair**

Carl Andersen  
Lawrence Ayers\*  
Alex Baker\*  
Robert Berger  
Randall Bergin\*  
Rolf Bergman  
Eric Bretschneider  
Daniel Brooks\*  
Kevin Broughton\*  
David Chan\*  
Pei-Ting Chou\*  
Richard Collins\*  
Ku'uipo Curry\*  
Russell Dahl\*  
Ronald Daubach\*  
David Ellis  
Adam Foy\*  
Peter Franck\*  
Richard Heinisch\*  
Kyle Hemmi\*  
Tanya Hernandez\*  
Robert Horan  
James Hospodarsky  
Shuming Hua\*  
Po-Chieh Hung\*  
Donald Husby\*\*

Stephen Hutton\*  
Andrew Jackson  
David Jenkins\*  
Jianzhong Jiao\*  
Hoon Sung Jung  
Michael Kalkas  
Demetrios Karambelas  
Hamid Kashani\*  
Ryan Kelley\*  
Mihaly Kotrebai  
Kevin Krueger  
Becky Kuebler\*  
John Lawton\*  
Lorence Leetzow\*  
Kelly Lerbs\*  
Robert Levin\*  
Ian Lewin  
Richard Li\*  
Robert Low\*  
Joseph Marella  
Philip McCarthy\*  
Greg McKee  
C. Cameron Miller  
Bruce Mosher  
Waneta Newland  
Yoshihiro Ohno\*

Gerard Plank\*  
Emil Radkov  
David Randolph  
Eric Richman\*  
Michael Riebling\*  
Mark Sapcoe  
Jason Schutz\*  
Andrew Smith\*  
Donald Smith\*  
Joong Kon Son\*  
Robert Speck\*\*  
Lloyd Stafford\*  
Gary Steinberg  
Ralph Tuttle  
Ken Wagner\*  
James Walker\*  
Heather Waugh\*  
Joseph Welch\*  
Kurt Wilcox\*  
Jeremy Yon\*  
John Zhang

\*Advisory

\*\*Honorary



# Contents

Foreword .....	1
1.0 Introduction .....	1
2.0 Normative References .....	1
3.0 Nomenclature and Definitions .....	1
4.0 Ambient and Physical Conditions.....	2
4.1 General .....	2
4.2 Vibration.....	2
4.3 Temperature.....	2
4.4 Air Movement .....	2
4.5 Operating Orientation and Lamp Spacing .....	2
5.0 Electrical Conditions.....	2
5.1 Input Voltage .....	2
5.2 Line Voltage Waveshape.....	2
5.3 Voltage Regulation.....	3
5.4 Ballast.....	3
5.5 Instrumentation .....	3
5.6 Wiring .....	3
5.7 Lamp Connections .....	3
5.8 Safety Considerations.....	3
6.0 Lamp Test Procedures .....	3
6.1 Lamp Selection .....	3
6.2 Lamp Handling .....	3
6.3 Lamp Marking.....	4
6.4 Operating Cycle.....	4
6.5 Recording Failures.....	4
7.0 Test Report.....	4
Informative References.....	4
IES References.....	5
ANSI References.....	5
Annex A .....	5



---

## FOREWORD

---

This approved method is a revision of IESNA LM-47-2001, IESNA Approved Method for Life Testing of High Intensity Discharge (HID) Lamps; changes have been made to update information, to give clearer guidelines for test requirements, and to promote uniformity in measurement procedures.

---

## INTRODUCTION

---

- This guide describes the procedures by which high intensity discharge (HID) lamps can be operated under controlled conditions to obtain optimally comparable data on individual lamp life, changes in light output, and other parameters that vary during the life of the lamp.
- HID lamps are characterized as light producing discharge devices whose discharge containment envelopes have a surface loading in excess of three watts per square centimeter. Additional characteristics of these lamp types are found in references 1 through 5.
- Light is produced in a high intensity discharge lamp by passing current through a vapor at relatively high pressure. Arc tube pressures for HID lamps can range from just less than one to as much as five atmospheres during lamp operation.
- In a high-pressure sodium lamp (HPS) the arc discharge passes through combined vapors of mercury and sodium. The sodium radiation dominates the color appearance of the light produced, which is characteristically gold and contains a minimal ultraviolet energy output.
- Light is produced in the metal halide (MH) lamp by an electrical discharge through combined vapors of mercury and other metals. These metals have the effect of increasing the light output in the blue, green, and yellow-red bands of the visual spectrum. Due to the spectral energy distribution in the lamp output from the metal vapors, the color appearance of MH HID lamps is nearly white. In addition to visible light, ultraviolet energy is also produced in the arc and is used in phosphor coated lamps to improve color characteristics.
- In mercury vapor lamps, light is generated by electric discharge through a vapor of mercury. The light produced is bright white, often with

the blue green cast. The color is dramatically improved by adding a phosphor coating to the outer bulb.

- It is often important to know the light output, efficacy, and lamp lumen maintenance along with the life of these lamps. The annex to this document discusses this issue. For information on the photometry of HID lamps, see reference 13.
- HID lamps are affected by many variables such as operating cycle, conditions imposed by auxiliary equipment, ambient temperature, vibration, airflow, and orientation. Test conditions and programs should be designed to give comparable results when adopted by various laboratories. The recommendations of this IES Approved Method have been made with these objectives in mind.

---

## 1.0 SCOPE

---

This approved method describes the procedures to be followed and the precautions to be observed in obtaining uniform and reproducible measurements during life testing of high intensity discharge lamps under standard conditions. This Approved Method includes other technologies within the Metal Halide family including Ceramic Metal Halide and Pulse Start Metal Halide lamps. It addresses life testing of high intensity discharge lamps operated on auxiliary devices, either external or integrated, designed and certified to meet lamp industry standards and tolerance. Xenon arc lamps, low-pressure sodium lamps, and automotive lamps are not addressed in this IES Approved Method.

---

## 2.0 NORMATIVE REFERENCES

---

No normative references

---

## 3.0 NOMENCLATURE AND DEFINITIONS

---

- a) The units of electrical measurement used in this approved method are the volt, the ampere, and the watt.
- b) Life of a test lamp refers to the actual operating time of the lamp, until failure expressed in hours, and shall not include any off time.