



ATIS-0600315.2022

**Voltage Levels for DC-Powered Equipment Used in
the Telecommunications Environment**

AMERICAN NATIONAL STANDARD FOR TELECOMMUNICATIONS



As a leading technology and solutions development organization, ATIS brings together the top global ICT companies to advance the industry's most-pressing business priorities. Through ATIS committees and forums, nearly 200 companies address cloud services, device solutions, emergency services, M2M communications, cyber security, ehealth, network evolution, quality of service, billing support, operations, and more. These priorities follow a fast-track development lifecycle — from design and innovation through solutions that include standards, specifications, requirements, business use cases, software toolkits, and interoperability testing.

ATIS is accredited by the American National Standards Institute (ANSI). ATIS is the North American Organizational Partner for the 3rd Generation Partnership Project (3GPP), a founding Partner of oneM2M, a member and major U.S. contributor to the International Telecommunication Union (ITU) Radio and Telecommunications sectors, and a member of the Inter-American Telecommunication Commission (CITEL). For more information, visit < www.atis.org >.

AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires review by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made towards their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

CAUTION NOTICE: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Notice of Disclaimer & Limitation of Liability

The information provided in this document is directed solely to professionals who have the appropriate degree of experience to understand and interpret its contents in accordance with generally accepted engineering or other professional standards and applicable regulations. No recommendation as to products or vendors is made or should be implied.

NO REPRESENTATION OR WARRANTY IS MADE THAT THE INFORMATION IS TECHNICALLY ACCURATE OR SUFFICIENT OR CONFORMS TO ANY STATUTE, GOVERNMENTAL RULE OR REGULATION, AND FURTHER, NO REPRESENTATION OR WARRANTY IS MADE OF MERCHANTABILITY OR FITNESS FOR ANY PARTICULAR PURPOSE OR AGAINST INFRINGEMENT OF INTELLECTUAL PROPERTY RIGHTS. ATIS SHALL NOT BE LIABLE, BEYOND THE AMOUNT OF ANY SUM RECEIVED IN PAYMENT BY ATIS FOR THIS DOCUMENT, AND IN NO EVENT SHALL ATIS BE LIABLE FOR LOST PROFITS OR OTHER INCIDENTAL OR CONSEQUENTIAL DAMAGES. ATIS EXPRESSLY ADVISES THAT ANY AND ALL USE OF OR RELIANCE UPON THE INFORMATION PROVIDED IN THIS DOCUMENT IS AT THE RISK OF THE USER.

<p>NOTE - The user's attention is called to the possibility that compliance with this standard may require use of an invention covered by patent rights. By publication of this standard, no position is taken with respect to whether use of an invention covered by patent rights will be required, and if any such use is required no position is taken regarding the validity of this claim or any patent rights in connection therewith. Please refer to [http://www.atis.org/legal/patentinfo.asp] to determine if any statement has been filed by a patent holder indicating a willingness to grant a license either without compensation or on reasonable and non-discriminatory terms and conditions to applicants desiring to obtain a license.</p>
--

ATIS-0600315.2022, *Voltage Levels for DC-Powered Equipment Used in the Telecommunications Environment*
Is an American National Standard developed by the **Network Power Systems (NPS)** Subcommittee under the **ATIS Sustainability in Telecom: Energy and Protection Committee (STEP)**.

Published by
Alliance for Telecommunications Industry Solutions
1200 G Street, NW, Suite 500
Washington, DC 20005

Copyright © 2022 by Alliance for Telecommunications Industry Solutions
All rights reserved.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher. For information contact ATIS at 202.628.6380. ATIS is online at < <http://www.atis.org> >.

ATIS-0600315.2022

(Revision of ATIS-0600315.2018)

American National Standard for Telecommunications

Voltage Levels for DC-Powered Equipment Used in the Telecommunications Environment

Alliance for Telecommunications Industry Solutions

Approved March 18, 2022

American National Standards Institute, Inc.

Abstract

This standard establishes requirements and test procedures for voltage ranges and characteristics associated with the input voltage of telecommunications equipment powered from dc power systems in the telecommunications environment. It includes +12, + and -24, -48, + and -130, and 140 VDC.

Foreword

The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with ANSI's requirements for an ANS. As such, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

The Alliance for Telecommunications Industry Solutions (ATIS) serves the public through improved understanding between providers, customers, and manufacturers. The Sustainability in Telecom: Energy and Protection (STEP) Committee – formerly the Network Interface, Power, and Protection Committee (NIPP) – engages industry expertise to develop standards and technical reports for telecommunications equipment and environments in the areas of energy efficiency, environmental impacts, power and protection. The work products of STEP enable vendors, operators and their customers to deploy and operate reliable, environmentally sustainable, energy efficient communications technologies. STEP is committed to proactive engagement with national, regional and international standards development organizations and forums that share its scope of work.

ANSI guidelines specify two categories of requirements: mandatory and recommendation. The mandatory requirements are designated by the word *shall* and recommendations by the word *should*. Where both a mandatory requirement and a recommendation are specified for the same criterion, the recommendation represents a goal currently identifiable as having distinct compatibility or performance advantages.

Suggestions for improvement of this document are welcome. They should be sent to the Alliance for Telecommunications Industry Solutions, STEP, 1200 G Street NW, Suite 500, Washington, DC 20005.

At the time of initiation or issuance of the letter ballot for this document, STEP, which was responsible for its development, had the following leadership:

- J. Fuller, STEP Chair and STEP NPS Vice Chair (AT&T)
- E. Gallo, STEP Vice Chair and STEP NPS Chair (Ericsson)
- J. Wiese, Technical Editor (ADTRAN)

The Network Power Systems (NPS) Subcommittee was responsible for the development of this document.

Table of Contents

1	Scope & Purpose	1
1.1	Scope	1
1.2	Purpose	1
2	References	2
2.1	Normative References	2
2.2	Informative References	2
3	Definitions, Abbreviations, & Acronyms	3
3.1	Definitions	3
3.2	Abbreviations & Acronyms	3
4	General Information	3
4.1	Power Plant & Telecommunications Load Equipment	3
4.2	Applications of Telecommunications Equipment	4
4.3	General Test Report Requirements	4
5	Telecommunications Load Equipment Performance Requirements	4
5.1	Steady-State Input DC Voltage Requirements	5
5.1.1	<i>Distribution Voltage Drops</i>	6
5.2	Undervoltage Requirements	6
5.2.1	<i>Minimum Operating Voltage Test Procedure for Nominal -48 Vdc equipment</i>	7
5.3	Overvoltage Requirements	8
5.3.1	<i>Maximum Operating Voltage Test Procedure</i>	8
5.3.2	<i>Maximum Operating Voltage Conformance</i>	9
5.3.3	<i>Maximum Operating Voltage Test Report</i>	9
5.4	75 Vdc Overvoltage Transient Requirement	9
5.4.1	<i>Overvoltage Transient Test Procedure for Nominal -48 Vdc Equipment</i>	9
5.4.2	<i>Overvoltage Transient Conformance</i>	9
5.4.3	<i>Overvoltage Transient Test Report</i>	10
5.5	Protective Device Operation Transient	10
5.5.1	<i>Protective Device Operation Transient for Nominal -48 Vdc Equipment Test Procedure</i>	14
5.5.2	<i>Protective Device Operation Transient Conformance</i>	16
5.5.3	<i>Protective Device Operation Transient Test Report</i>	17
5.6	Electrical Noise Requirements	17
5.6.1	<i>Noise Immunity</i>	17
5.6.2	<i>Noise Returned by the Telecommunications Load Equipment (TLE)</i>	19
6	Other Requirements	21
6.1	Basis for MTBF Calculation	21
6.2	Personnel Hazards	22
6.3	Marking & Documentation	22
6.3.1	<i>Marking & Documentation Test Report</i>	22
A	Telecommunications Load Equipment Voltage	23
B	Compliance Testing	24
B.1	Test Method Using the Single Transient in Figure 5.1	24
B.2	Test Method Using the Separate Transients in Figures 5.2 through 5.4	24
B.2.1	<i>Impulse Transient, Waveform Figure 5.2, & Test Circuit Figure B.2</i>	24
B.2.2	<i>Overvoltage Transient, Waveform Figure 5.3, & Test Circuit Figure B.3 (see IEC 61000-4-11)</i>	25
B.2.3	<i>Undervoltage Transient, Waveform Figure 5.4, & Test Circuit Figure B.4 (see IEC 61000-4-11)</i>	26

C Approximation for Inductance of a Solenoid..... 27

D Specialized TLE turn-on voltage criteria..... 28

Table of Figures

Figure 5.1 – Total Protective Device Operation Transient 11

Figure 5.2 - Impulse Protective Device Operation Transient 12

Figure 5.3 - Overvoltage Protective Device Operation Transient..... 13

Figure 5.4 - Undervoltage Protective Device Operation Transient..... 14

Figure 5.5 - Noise Immunity Test Circuit..... 18

Figure 5.6 - Noise Return Test Circuit 20

Figure B.1 - Transient Compliance Test Circuit 24

Figure B.2 - Impulse Test 25

Figure B.3 - Overvoltage Transient..... 25

Figure B.4 - Undervoltage Transient..... 26

Table of Tables

Table 5.1 - Telecommunications load equipment operating requirements for 12-, 24-, and 48-V nominal voltage plants 5

Table 5.2 - Telecommunications load equipment operating requirements for 130- and 140-V nominal voltage plants 6

Table 5.3 - Selection of Calibration Resistance or maximum Output Impedance 16

Table 6.1 - Voltage reference for MTBF calculations..... 21

American National Standard for Telecommunications –

Voltage Levels for DC-Powered Equipment Used in the Telecommunications Environment

1 Scope & Purpose

1.1 Scope

This standard establishes requirements and test procedures for certain voltage ranges and characteristics (i.e., transients and noise) associated with the input voltage of network telecommunications equipment powered from dc power systems in the telecommunications environment in carrier communications space. This standard also provides reporting criteria for results obtained during the testing of equipment.

This standard does not:

- Include test procedures for systems operating at other than nominal 48 Vdc in Sections 5.2.1, 5.4, 5.5, or 5.6.
- Specify dc power plant voltage levels.
- Specify the voltage applied to the interface between the network and customer installations (i.e., network span voltages or voltages at the customer interface).
- Apply to equipment intended to be powered from the telecommunications span.
- Apply to equipment intended to be solely powered by a pluggable power supply.

1.2 Purpose

The purpose of this standard is to specify:

- The steady-state dc input voltage ranges over which telecommunications load equipment (TLE) is required to operate when connected to the nominal voltage power plants addressed in this standard;
- Transient voltage tolerance requirements for TLE;
- Noise immunity for TLE;
- Limits for noise returned by the TLE;
- Voltage levels for uniform Mean-Time-Between-Failure (MTBF) calculations;
- Undervoltage requirements;
- Overvoltage requirements;
- Test procedures;
- Test report criteria;
- Personnel hazards; and
- Marking.

This standard is intended to be applied to equipment designed and manufactured after the effective issue date of this standard. Nothing in this standard should be interpreted to require the retrofitting of existing TLE or power plants. This standard does not restrict the development or use of telecommunications architectures that use other voltage levels and ranges.