



**ATIS-0600332.2020**

**Electrical Protection of  
Network-Powered Broadband Facilities**

**AMERICAN NATIONAL STANDARD FOR TELECOMMUNICATIONS**



---

As a leading technology and solutions development organization, the Alliance for Telecommunications Industry Solutions (ATIS) brings together the top global ICT companies to advance the industry's most pressing business priorities. ATIS' nearly 200 member companies are currently working to address the All-IP transition, 5G, network functions virtualization, big data analytics, cloud services, device solutions, emergency services, M2M, cyber security, network evolution, quality of service, billing support, operations, and much more. These priorities follow a fast-track development lifecycle — from design and innovation through standards, specifications, requirements, business use cases, software toolkits, open source solutions, and interoperability testing.

ATIS is accredited by the American National Standards Institute (ANSI). The organization is the North American Organizational Partner for the 3rd Generation Partnership Project (3GPP), a founding Partner of the oneM2M global initiative, a member of the International Telecommunication Union (ITU), as well as a member of the Inter-American Telecommunication Commission (CITEL). For more information, visit [www.atis.org](http://www.atis.org).

---

## AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires review by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made towards their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

**CAUTION NOTICE:** This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

---

## Notice of Disclaimer & Limitation of Liability

The information provided in this document is directed solely to professionals who have the appropriate degree of experience to understand and interpret its contents in accordance with generally accepted engineering or other professional standards and applicable regulations. No recommendation as to products or vendors is made or should be implied.

NO REPRESENTATION OR WARRANTY IS MADE THAT THE INFORMATION IS TECHNICALLY ACCURATE OR SUFFICIENT OR CONFORMS TO ANY STATUTE, GOVERNMENTAL RULE OR REGULATION, AND FURTHER, NO REPRESENTATION OR WARRANTY IS MADE OF MERCHANTABILITY OR FITNESS FOR ANY PARTICULAR PURPOSE OR AGAINST INFRINGEMENT OF INTELLECTUAL PROPERTY RIGHTS. ATIS SHALL NOT BE LIABLE, BEYOND THE AMOUNT OF ANY SUM RECEIVED IN PAYMENT BY ATIS FOR THIS DOCUMENT, AND IN NO EVENT SHALL ATIS BE LIABLE FOR LOST PROFITS OR OTHER INCIDENTAL OR CONSEQUENTIAL DAMAGES. ATIS EXPRESSLY ADVISES THAT ANY AND ALL USE OF OR RELIANCE UPON THE INFORMATION PROVIDED IN THIS DOCUMENT IS AT THE RISK OF THE USER.

NOTE - The user's attention is called to the possibility that compliance with this standard may require use of an invention covered by patent rights. By publication of this standard, no position is taken with respect to whether use of an invention covered by patent rights will be required, and if any such use is required no position is taken regarding the validity of this claim or any patent rights in connection therewith. Please refer to [<http://www.atis.org/legal/patentinfo.asp>] to determine if any statement has been filed by a patent holder indicating a willingness to grant a license either without compensation or on reasonable and non-discriminatory terms and conditions to applicants desiring to obtain a license.

---

## ATIS-0600332.2020, *Electrical Protection of Network-Powered Broadband Facilities*

Is an American National Standard developed by the ATIS **Network Electrical Protection (NEP)** Subcommittee under the **ATIS Sustainability in Telecom: Energy and Protection Committee (STEP)**.

*Published by*

**Alliance for Telecommunications Industry Solutions**  
**1200 G Street, NW, Suite 500**  
**Washington, DC 20005**

Copyright © 2020 by Alliance for Telecommunications Industry Solutions  
All rights reserved.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher. For information contact ATIS at 202.628.6380. ATIS is online at < <http://www.atis.org> >.

**ATIS-0600332.2020**

[Revision of ATIS-0600332.2015]

**American National Standard for Telecommunications**

# **Electrical Protection of Network-Powered Broadband Facilities**

**Alliance for Telecommunications Industry Solutions**

Approved July 16, 2020

**American National Standards Institute, Inc.**

## **Abstract**

This standard provides the minimum electrical protection requirements intended to mitigate the disruptive and damaging effects of lightning and ac power faults to broadband facilities. Disturbances from lightning and ac power line faults may be disruptive to broadband service and may also result in damage to the broadband plant and equipment. Head ends, switching centers and similar type facilities, outside plant cables, and the interface point at customer locations are often exposed to such disturbances, either directly or through the broadband cables and ac power facilities that serve them. Telecommunications service providers employ electrical protection measures and bonding and ground techniques to reduce the effects of such disturbances.

## Foreword

---

The information contained in this Foreword is not part of this American National Standard (ANS) and has not been processed in accordance with the American National Standards Institute's (ANSI) requirements for an ANS. As such, this Foreword may contain material that has not been subjected to public review or a consensus process. In addition, it does not contain requirements necessary for conformance to the Standard.

The Alliance for Telecommunication Industry Solutions (ATIS) serves the public through improved understanding between providers, customers, and manufacturers. The Sustainability in Telecom: Energy and Protection (STEP) Committee – formerly the Network Interface, Power, and Protection Committee (NIPP) – engages industry expertise to develop standards and technical reports for telecommunications equipment and environments in the areas of energy efficiency, environmental impacts, power, and protection. The work products of STEP enable vendors, operators, and their customers to deploy and operate reliable, environmentally sustainable, energy efficient communications technologies. STEP is committed to proactive engagement with national, regional, and international standards development organizations and forums that share its scope of work.

ANSI guidelines specify two categories of requirements: mandatory and recommendation. The mandatory requirements are designated by the word shall and recommendations by the word should. Where both a mandatory requirement and a recommendation are specified for the same criterion, the recommendation represents a goal currently identifiable as having distinct compatibility or performance advantages.

Suggestions for improvement of this document are welcome. They should be sent to the Alliance for Telecommunications Industry Solutions, STEP, 1200 G Street NW, Suite 500, Washington, DC 20005.

At the time it approved this document, STEP, which is responsible for the development of this Standard, had the following leadership:

- E. Gallo, STEP Chair (Ericsson)
- J. Fuller, STEP Vice-Chair (AT&T)
- D. Ashton, STEP NEP Chair (CenturyLink)

The Network Electrical Protection (NEP) Subcommittee was responsible for the development of this document.

# Table of Contents

---

1	Scope, Purpose, & Application .....	1
1.1	Application of Electrical Protection .....	1
1.2	Facilities Covered .....	1
1.3	Items Not Covered .....	1
2	References .....	2
2.1	Normative .....	2
2.2	Informative .....	2
3	Definitions and Acronyms .....	3
3.1	Definitions .....	3
4	Exposure .....	4
4.1	Sources of Exposure .....	4
4.1.1	Lightning Disturbances .....	5
4.1.2	Contact with Power Circuits .....	5
4.1.3	Ground Potential Rise (GPR).....	5
4.1.4	Power Induction .....	5
4.1.5	Resistive Coupling .....	6
4.2	Classification of Exposure .....	6
4.2.1	Exposure to Lightning.....	6
4.2.2	Exposure to Power Contact .....	7
4.2.3	Exposure to Ground Potential Rise (GPR) .....	8
4.2.4	Exposure to Power Induction .....	8
5	Electrical Protection Considerations .....	8
5.1	General .....	8
5.1.1	National Electrical Code Considerations.....	8
5.1.2	National Electrical Safety Code Considerations .....	9
5.2	Bonding & Grounding .....	9
5.3	Primary Protectors .....	10
5.4	Fuse Links .....	10
5.5	Current-Limiting Devices .....	10
6	Switching Centers, Head-ends, & Similar Type Facilities .....	10
6.1	Protection of Entrance Facilities (Telecommunications) .....	10
6.1.1	Protectors .....	11
6.1.2	Bonding & Grounding .....	11
6.1.3	Protector Coordination .....	11
6.1.4	Application of Current-Limiting Devices .....	12
6.2	Protection of Entrance Facilities (Commercial AC).....	12
6.2.1	Determining Exposure .....	12
6.2.2	Sources of Overvoltage on the Serving ac Power Facility.....	12
6.2.3	Application of Surge Protective Devices .....	13
6.3	Microwave Towers & Satellite Dishes .....	13
6.3.1	Structure Grounding Requirements.....	13
6.3.2	Equipment Building Grounding Requirements .....	14
6.3.3	Waveguide & Coaxial Cable Grounding Requirements.....	14
6.3.4	Equipment Grounding Requirements .....	14
7	Outside Plant Cables & Equipment.....	15

7.1	General Exposure Considerations .....	15
7.2	Aerial Plant & Equipment .....	15
7.3	Buried Plant .....	15
7.4	Underground Plant.....	16
7.5	Bridges, Overpasses, Submarine Plant.....	16
7.6	General electrical Protection Measures.....	16
7.6.1	Separation & Clearances .....	16
7.6.2	Bonding & Grounding .....	16
7.6.3	Shielding.....	17
7.6.4	Cable Dielectric Coordination .....	17
7.6.5	Fuse Links .....	17
7.6.6	Support Strand Ampacity (I <sup>2</sup> t) .....	18
7.7	Specific Electrical Protection Measures .....	18
7.7.1	Aerial Plant & Equipment .....	18
7.7.2	Buried Plant & Equipment.....	18
7.7.3	Underground Plant & Equipment.....	19
8	Customer Locations.....	19
8.1	Exposure & Electrical Protection Considerations.....	19
8.1.1	General.....	19
8.1.2	Unexposed Locations.....	20
8.2	Application of Protection Measures At Customer Locations .....	20
8.2.1	General Network Interface Unit (NIU) Considerations.....	20
8.2.2	NIU Bonding Terminal.....	21
8.2.3	Protection of Exposed Ports .....	21
8.2.4	Protector(s) Location .....	21
8.2.5	Acceptable Grounds .....	21
8.2.6	Primary Protector Grounding Conductor Requirements .....	22
8.2.7	Multi-Port Protection .....	22
8.2.8	Multiple NIUs.....	23
8.2.9	Wireless Serving Terminal Bonding & Grounding.....	23
9	Installation Considerations.....	23
9.1	General.....	23
9.2	Objective.....	24
9.3	Grounding Materials.....	24
9.4	Grounding & Bonding Conductors.....	24
9.5	Conduit Use with Grounding Conductors .....	24
9.6	Ground Rods & Bare Conductors.....	24
9.7	Connections.....	24
10	Equipment Grounding.....	25
10.1	Equipment in the Outside Plant.....	25
10.2	Grounding of ac Fed Equipment & Power Supplies .....	25

## Table of Tables

Table 5.1 – Application of ANSI/NFPA 70 (NEC) at the output circuit of the NIU .....	9
Table 6.1 – Fuse Cable Requirements.....	11

American National Standard for Telecommunications –

# Electrical Protection of Network-Powered Broadband Facilities

## 1 Scope, Purpose, & Application

### 1.1 Application of Electrical Protection

The electrical protection, bonding, and grounding measures presented in this standard are intended to assist in protecting persons, equipment, and property from the effects of lightning, commercial ac power system faults, and electromagnetic interference (EMI) on the Network-powered broadband facilities.

### 1.2 Facilities Covered

This standard applies to the electrical protection, bonding, and grounding of network-powered broadband facilities at the headend, in the outside plant, and at the customer location (including the entrance or interface point). In some cases, the headend and the switching center might be collocated. These facilities may consist of paired conductor cable, optical fiber cable, or coaxial cable, either singularly or in any combination. The facilities may be aerial, buried, or underground.

The typical basic system configuration includes a cable supplying power and network-powered broadband signal to a network interface unit (NIU) that converts the network-powered broadband signal to the component signals. Typical cables are coaxial cable with both network-powered broadband signal and power on the center conductor, composite metallic cable with a coaxial member for the network-powered broadband signal and twisted pair(s) for power, and composite optical fiber cable with twisted pair(s) for power. Article 830 of National Electric Code® (NEC®) covers network-powered broadband communications systems at customer's structures or buildings, extending from the power-passing tap to the NIU.

### 1.3 Items Not Covered

Although a variety of existing and proposed network-powered broadband architectures are considered, the merits of the different technologies, and/or architecture types, are not covered.

The following items are also not covered by the standard:

- In-Premises wiring and components.
- Other customer premises equipment (CPE) from the network interface inward.
- Span-Powering, Power-over-Ethernet (PoE) and G.fast network applications – ATIS is currently developing standards covering the powering limits and electrical protection aspects of these architectures and applications.
- Specific EMI mitigation designs.
- Specifications for primary protectors.
- Microwave systems.
- Subscriber radio systems.
- Communications circuits as covered by National Electric Code® (NEC®) Article 800. Other ATIS standards such as ATIS-0600313 [Ref 4], ATIS-0600316 [Ref 5], and ATIS-0600318 cover these communications circuits.
- CATV as covered by NEC® Article 820.