

AS 60529:2025



Degrees of protection provided by enclosures (IP Code) (IEC 60529:1989 (ED. 2.2) MOD)



AS 60529:2025

This Australian Standard® was prepared by EL-026, Protective Enclosures and Environmental Testing for Electrical/Electronic Equipment. It was approved on behalf of Standards Australia's Standards Development and Accreditation Committee on 15 April 2025.

This Standard was published on 23 May 2025.

The following are represented on Committee EL-026:

- Australian Industry Group
- Consumer Electronics Suppliers Association
- Electrical Compliance Testing Association of Australia
- Electrical Regulatory Authorities Council, Australia
- Master Electricians Australia
- National Association of Testing Authorities Australia
- SafeworkNSW
- VIPAC (Testing Interests Australia)

This Standard was issued in draft form for comment as DR AS 60529:2024.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

ISBN 978 1 76175 157 8

Degrees of protection provided by enclosures (IP Code) (IEC 60529:1989 (ED. 2.2) MOD)

Originated as AS 60529—2004.
Second edition 2025.



© IEC Geneva Switzerland 2025 — All rights reserved
© Standards Australia Limited 2025

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of either the IEC or the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth). If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please see the contact details on the back cover or the contact us page of the website for further information.

How to read this Standard

This page explains the meaning of the language and structure of this Standard.

Refer to Standards Australia's [Standardisation Guide 006](#) for more details about drafting rules.

Australian and Australian/New Zealand Standards are voluntary unless they are referenced in legislation or called up in contracts.

Requirements

To conform to a Standard, all requirements in the Standard need to be met.

A requirement is any statement in the Standard which uses the word "shall".

Recommendations, permissions and possibilities

The following words are commonly used in Standards, but statements using them do not have to be followed to conform to the Standard:

- (a) "should" means that something is recommended.
- (b) "may" means that something is permitted.
- (c) "can" means that something is possible.

Structure of Standards

A Standard always has the following parts:

- (i) The Preface states who developed the Standard, what the Standard is aiming to do, and how it relates to other documents.
- (ii) The Scope states what the Standard is about, what it covers and what it does not cover.
- (iii) The Normative references clause lists other documents that are referenced in the Standard as part of requirements.
- (iv) The Terms and definitions clause defines important terms to help with understanding the Standard.

A Standard may also include other parts, such as the following:

- (1) A normative appendix sets additional requirements that need to be conformed to.
- (2) An informative appendix provides additional information or guidance. An informative appendix provides additional information or guidance. They usually do not contain requirements. If an informative appendix does contain requirements, the Technical Specification will explain when those requirements apply.
- (3) A Bibliography lists documents referenced in the Standard but not as part of requirements.

Many Standards include notes. Notes provide recommendations and/or guidance only. They never contain requirements.

This Standard is a modified adoption of an International Standard. It makes changes to the international text.

The changes to the international text are shown in boxes in the text. These boxes have the heading "National Variations".

To use this Standard in Australia/New Zealand, the changes in the national variation boxes need to be followed.

Preface

This Standard was prepared by the Standards Australia Committee EL-026, Protective Enclosures and Environmental Testing for Electrical/Electronic Equipment, to supersede AS 60529:2004.

AS 60529:2004 will also remain current for 24 months after the date of publication of this document and after this time it will be superseded by AS 60529:2025. Regulatory authorities that reference this document in regulation may apply these requirements at a different time. Users of this document should consult with these authorities to confirm their requirements.

The objective of this document is to provide the following:

- (a) Definitions for degrees of protection provided by enclosures of electrical equipment as regards —
 - (i) protection of persons against access to hazardous parts inside the enclosure;
 - (ii) protection of the equipment inside the enclosure against ingress of solid foreign objects; and
 - (iii) protection of the equipment inside the enclosure against harmful effects due to the ingress of water.
- (b) Designations for these degrees of protection.
- (c) Requirements for each designation.
- (d) Tests to be performed to verify that the enclosure meets the requirements of this standard.

This document is an adoption with national modifications and has been reproduced from IEC 60529:1989+AMD1:1999+AMD2:2013 CSV, *Degrees of protection provided by enclosures (IP code)*. The modifications are set out in national variations boxes which give instructions where the IEC text is to be modified for use in Australia. Due to IEC copyright policy it is not possible to directly modify the IEC content.

Appendix ZA provides additional requirements and guidance on the selection of test samples. It has been added at the end of the source text.

As this document has been reproduced from an International document, a full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

Contents

Preface.....	iii
FOREWORD.....	vii
INTRODUCTION.....	ix
INTRODUCTION TO AMENDMENT 2.....	x
1 Scope and object.....	1
2 Normative references.....	2
3 Definitions.....	2
4 Designations.....	4
4.1 Arrangement of the IP Code.....	4
4.2 Elements of the IP Code and their meanings.....	5
4.3 Examples for the use of letters in the IP Code.....	6
5 Degrees of protection against access to hazardous parts and against solid foreign objects indicated by the first characteristic numeral.....	7
5.1 Protection against access to hazardous parts.....	7
5.2 Protection against solid foreign objects.....	8
6 Degrees of protection against ingress of water indicated by the second characteristic numeral.....	9
7 Degrees of protection against access to hazardous parts indicated by the additional letter.....	11
8 Supplementary letters.....	12
9 Examples of designations with the IP Code.....	13
9.1 IP Code not using optional letters.....	13
9.2 IP Code using optional letters.....	14
10 Marking.....	14
11 General requirements for tests.....	15
11.1 Atmospheric conditions for water or dust tests.....	15
11.2 Test samples.....	15
11.3 Application of test requirements and interpretation of test results.....	16
11.4 Combination of test conditions for the first characteristic numeral.....	16
11.5 Empty enclosures.....	16
12 Tests for protection against access to hazardous parts indicated by the first characteristic numeral.....	16
12.1 Access probes.....	16
12.2 Test conditions.....	16
12.3 Acceptance conditions.....	18
12.3.1 For low-voltage equipment (rated voltages not exceeding 1 000 V a.c. and 1 500 V d.c.).....	18
12.3.2 For high-voltage equipment (rated voltages exceeding 1 000 V a.c. and 1 500 V d.c.).....	18
12.3.3 For equipment with hazardous mechanical parts.....	19
13 Tests for protection against solid foreign objects indicated by the first characteristic numeral.....	19
13.1 Test means.....	19
13.2 Test conditions for first characteristic numerals 1, 2, 3, 4.....	19
13.3 Acceptance conditions for first characteristic numerals 1, 2, 3, 4.....	20
13.4 Dust test for first characteristic numerals 5 and 6.....	20
13.5 Special conditions for first characteristic numeral 5.....	21
13.5.1 Test conditions for first characteristic numeral 5.....	21

13.5.2	Acceptance conditions for first characteristic numeral 5	21
13.6	Special conditions for first characteristic numeral 6	21
13.6.1	Test conditions for first characteristic numeral 6	21
13.6.2	Acceptance conditions for first characteristic numeral 6	21
14	Tests for protection against water indicated by the second characteristic numeral	22
14.1	Test means	22
14.2	Test conditions	23
14.2.1	Test for second characteristic numeral 1 with the drip box	23
14.2.2	Test for second characteristic numeral 2 with the drip box	23
14.2.3	Test for second characteristic numeral 3 with oscillating tube or spray nozzle	24
14.2.4	Test for second characteristic numeral 4 with oscillating tube or spray nozzle	24
14.2.5	Test for second characteristic numeral 5 with the 6,3 mm nozzle	25
14.2.6	Test for second characteristic numeral 6 with the 12,5 mm nozzle	25
14.2.7	Test for second characteristic numeral 7: temporary immersion between 0,15 m and 1 m	26
14.2.8	Test for second characteristic numeral 8: continuous immersion subject to agreement	26
14.2.9	Test for second characteristic numeral 9 by high pressure and temperature water jetting	26
14.3	Acceptance conditions	27
15	Tests for protection against access to hazardous parts indicated by the additional letter	27
15.1	Access probes	27
15.2	Test conditions	28
15.3	Acceptance conditions	28
Annex A	(informative) Examples of IP coding for the verification of protection of low-voltage equipment against access to hazardous parts	39
Annex B	(informative) Summary of responsibilities of relevant technical committees	44
Bibliography	46
Appendix ZA	(informative) Verification of an IP rating using test samples	47

List of Figures

Figure 1	— Jointed test finger	30
Figure 2	— Test device to verify protection against dust (dust chamber)	30
Figure 3	— Test device to verify protection against vertically falling water drops (drip box)	31
Figure 4	— Test device to verify protection against spraying and splashing water; second characteristic numerals 3 and 4 (oscillating tube)	32
Figure 5	— Hand-held device to verify protection against spraying and splashing water; second characteristic numerals 3 and 4 (spray nozzle)	33
Figure 6	— Test device to verify protection against water jets (hose nozzle)	34
Figure 7	— Fan jet nozzle dimensions	34
Figure 8	— Fan jet nozzle resulting dimensions of spraying hole for checking purpose	35
Figure 9	— Example of different quality achievements of the surface finish of the fan jet nozzle	36
Figure 10	— Set-up for measuring the impact force of the water jet for determining the protection against high pressure and temperature water jet, degree of protection against ingress of water IP X9	37
Figure 11	— Impact force distribution	37
Figure 12	— Test set-up for determining the protection against high-pressure and temperature water jet; degree of protection against ingress of water IP X9 for small enclosures	38

List of Tables

Table 1 — Degrees of protection against access to hazardous parts indicated by the first characteristic numeral	8
Table 2 — Degrees of protection against solid foreign objects indicated by the first characteristic numeral	9
Table 3 — Degrees of protection against water indicated by the second characteristic numeral.....	10
Table 4 — Degrees of protection against access to hazardous parts indicated by the additional letter	12
Table 5 — Test conditions for degrees of protection indicated by the first characteristic numeral.....	16
Table 6 — Access probes for the tests for protection of persons against access to hazardous parts.....	17
Table 7 — Test means for the tests for protection against solid foreign objects.....	19
Table 8 — Test means and main test conditions for the tests for protection against water.....	22
Table 9 — Total water flow rate q_v under IPX3 and IPX4 test conditions – Mean flow rate per hole $q_{vl} = 0,07$ l/min	25
IP Codes of examples in Annex A	43
Table ZA.1 — Comparison with a test sample	48

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

This consolidated version of the official IEC Standard and its amendments has been prepared for user convenience.

IEC 60529 edition 2.2 contains the second edition (1989) [documents 70(CO)13 + 70(CO)15 and 70(CO)16 + 70(CO)17], its corrigendum 1 (2003), its corrigendum 2 (2007), its corrigendum 3 (2009), its amendment 1 (1999) [documents 70/91/FDIS and 70/92/RVD] and its amendment 2 [documents 70/122/FDIS and 70/123/RVD].

This Final version does not show where the technical content is modified by amendments 1 and 2. A separate Redline version with all changes highlighted is available in this publication.

International Standard IEC 60529 has been prepared by technical committee 70: Degrees of protection by enclosures.

Annexes A and B are for information only.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

The committee has decided that the contents of the base publication and its amendments will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

The contents of the corrigenda of October 2013, May 2015 and January 2019 have been included in this copy.

IMPORTANT - The "colour inside" logo on the cover page of this publication indicates that it contains colours which are considered to be useful for the correct understanding of its contents. Users should therefore print this publication using a colour printer.

INTRODUCTION

This standard describes a system for classifying the degrees of protection provided by the enclosures of electrical equipment. While this system is suitable for use with most types of electrical equipment, it should not be assumed that all the listed degrees of protection are applicable to a particular type of equipment. The manufacturer of the equipment should be consulted to determine the degrees of protection available and the parts of equipment to which the stated degree of protection applies.

The adoption of this classification system, wherever possible, will promote uniformity in methods of describing the protection provided by the enclosure and in the tests to prove the various degrees of protection. It should also reduce the number of types of test devices necessary to test a wide range of products.

This second edition of IEC 60529 takes account of experiences with the first edition, and clarifies the requirements. It provides for an optional extension of the IP Code by an additional letter A, B, C, or D if the actual protection of persons against access to hazardous parts is higher than that indicated by the first characteristic numeral.

In general, enclosures with an IP coding to the first edition would be eligible for the same code according to this edition.

INTRODUCTION TO AMENDMENT 2

This Amendment 2 introduces a new degree of protection IP X9 whereas no modifications of the existing degrees of protection are made.

Thus neither additional tests nor modifications of the existing certificates should be requested in case of enclosures providing a different IP code.

Australian Standard®

Degrees of protection provided by enclosures (IP Code) (IEC 60529:1989 (ED. 2.2) MOD)

1 Scope and object

This standard applies to the classification of degrees of protection provided by enclosures for electrical equipment with a rated voltage not exceeding 72,5 kV.

The object of this standard is to give:

- a) *Definitions* for degrees of protection provided by enclosures of electrical equipment as regards:
 - 1) protection of persons against access to hazardous parts inside the enclosure;
 - 2) protection of the equipment inside the enclosure against ingress of solid foreign objects;
 - 3) protection of the equipment inside the enclosure against harmful effects due to the ingress of water.
- b) *Designations* for these degrees of protection.
- c) *Requirements* for each designation.
- d) *Tests* to be performed to verify that the enclosure meets the requirements of this standard.

It will remain the responsibility of individual technical committees to decide on the extent and manner in which, the classification is used in their standards and to define “enclosure” as it applies to their equipment. However, it is recommended that for a given classification the tests do not differ from those specified in this standard. If necessary, complementary requirements may be included in the relevant product standard. A guide for the details to be specified in relevant product standards is given in Annex B.

For a particular type of equipment, a technical committee may specify different requirements provided that at least the same level of safety is ensured.

This standard deals only with enclosures that are in all other respects suitable for their intended use as specified in the relevant product standard and which from the point of view of materials and workmanship ensure that the claimed degrees of protection are maintained under the normal conditions of use.

This standard is also applicable to empty enclosures provided that the general test requirements are met and that the selected degree of protection is suitable for the type of equipment to be protected.

Measures to protect both the enclosure and the equipment inside the enclosure against external influences or conditions such as

- mechanical impacts
- corrosion
- corrosive solvents (for example, cutting liquids)
- fungus
- vermin
- solar radiation
- icing