

AS/NZS 60255.1:2025



Australian/New Zealand Standard™

Measuring relays and protection equipment

Part 1: Common requirements (IEC 60255-1:2022 (ED. 2.0) MOD)



AS/NZS 60255.1:2025

This Joint Australian/New Zealand Standard™ was prepared by Joint Technical Committee EL-042, Renewable Energy Power Supply Systems & Equipment. It was approved on behalf of Standards Australia's Standards Development and Accreditation Committee on 16 January 2025 and by the New Zealand Standards Approval Board on 11 December 2024.

This Standard was published on 28 February 2025.

The following are represented on Committee EL-042:

Australasian Fire and Emergency Service Authorities Council
Australian Energy Council
Australian Energy Market Operator
Australian Industry Group
Australian PV Institute
Better Regulation Division (Fair Trading, SafeWork NSW, TestSafe)
CSIRO
Clean Energy Council
Clean Energy Regulator
Consumer Electronics Suppliers Association
Consumers' Federation of Australia
Electrical Compliance Testing Association of Australia
Electrical Regulatory Authorities Council, Australia
Electrical Safety New Zealand
Electricity Authority of New Zealand
Electricity Engineers Association of New Zealand
Energy Efficiency & Conservation Authority of New Zealand
Energy Networks Australia
Energy Skills Australia
Engineers Australia
Institute of Electrical Inspectors
Institute of Electrical and Electronics Engineers
Institution of Fire Engineers (NZ Branch)
Joint Accreditation System of Australia & New Zealand
Master Electricians Australia
National Electrical and Communications Association
Office of the Technical Regulator (SA)
Smart Energy Council
Solar Energy Industries Association
Sustainable Electricity Association New Zealand
The Institution of Engineering and Technology
University of New South Wales
Vector
WorkSafe New Zealand

This Standard was issued in draft form for comment as DR AS/NZS 60255.1:2024.

Keeping Standards up-to-date

Ensure you have the latest versions of our publications and keep up-to-date about Amendments, Rulings, Withdrawals, and new projects by visiting:

www.standards.org.au

www.standards.govt.nz

ISBN 978 1 76175 047 2

Australian/New Zealand Standard™

Measuring relays and protection equipment

Part 1: Common requirements (IEC 60255-1:2022 (ED. 2.0) MOD)

First published as AS/NZS 60255.1:2025.



© IEC Geneva Switzerland 2025 — All rights reserved

© Standards Australia Limited/the Crown in right of New Zealand, administered by the New Zealand Standards Executive 2025

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of either the IEC or the publisher, unless otherwise permitted under the Copyright Act 1968 (Cth) or the Copyright Act 1994 (New Zealand). If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please see the contact details on the back cover or the contact us page of the website for further information.

Preface

This Standard prepared by the Joint Standards Australia/Standards New Zealand Committee EL-042, Renewable Energy Power Supply Systems and Equipment.

The objective of this document is to specify common rules and requirements applicable to measuring relays and protection equipment, including any combination of equipment to form a distributed protection scheme for power system protection such as control, monitoring and process interface equipment, to obtain uniformity of requirements and tests. This document covers the main technologies in use today; other emerging technologies present specific EMC and safety issues but the philosophy in this document will be applied.

All measuring relays and protection equipment used for protection within the power system environment are covered by this document. Other documents in this series can define their own requirements which in such cases take precedence. The typical locations for measuring relays and protection equipment are where protection of electrical equipment is required: generally power stations, substations and industrial locations.

Measuring relays and protection equipment installed in special applications (marine, railways, aerospace, explosive atmospheres, computer centres, etc.) could be enhanced by additional requirements required by that application.

This document is an adoption with national modifications, and has been reproduced from IEC 60255-1:2022, *Measuring relays and protection equipment — Part 1: Common requirements*. The modifications are set out in national variations boxes which give instructions where the IEC text is to be modified for use in Australia. Due to IEC copyright policy it is not possible to directly modify the IEC content.

As this document has been reproduced from an international document, the following apply:

- (a) In the source text “This part of IEC 60255” should read “This document”.
- (b) A full point substitutes for a comma when referring to a decimal marker.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably. Refer to the online catalogue for information on specific Standards.

The terms “normative” and “informative” are used in Standards to define the application of the appendices or annexes to which they apply. A “normative” appendix or annex is an integral part of a Standard, whereas an “informative” appendix or annex is only for information and guidance.

Contents

Preface	ii
FOREWORD	vi
INTRODUCTION	viii
1 Scope	1
2 Normative references	1
3 Terms, definitions and abbreviated terms	3
3.1 Terms and definitions	3
3.2 Abbreviated terms	9
4 Environmental conditions	9
4.1 General	9
4.2 Normal environmental conditions	10
4.3 Special environmental conditions	10
4.4 Environmental storage conditions	10
4.5 Transport conditions	10
5 Ratings	11
5.1 General	11
5.2 Rated voltage	11
5.2.1 Input energizing voltage	11
5.2.2 Auxiliary power supply port energizing voltage	11
5.2.3 Rated insulation voltage	11
5.3 Rated current – Input energizing current	12
5.3.1 Primary relay	12
5.3.2 Secondary relay	12
5.4 Binary input and output port	12
5.4.1 Binary input port	12
5.4.2 Binary output port	12
5.5 Transducer analogue input and output port	13
5.5.1 Transducer analogue input port	13
5.5.2 Transducer analogue output port	13
5.6 Frequency	13
5.6.1 Rated frequency	13
5.6.2 Frequency operating range	13
5.7 Rated burden	14
5.8 Rated ambient temperature range	14
6 Design and construction	14
6.1 Marking	14
6.2 Dimensions	14
6.3 Enclosure protection	14
6.4 Product safety requirements	14
6.5 Functional performance requirements	15
6.5.1 General	15
6.5.2 Intrinsic accuracy	15
6.5.3 Operating accuracy	16
6.5.4 Performance under system conditions	16
6.5.5 Performance of multifunctional protection equipment	16
6.5.6 Internal user programmable logic	16
6.6 Communication protocols	16
6.7 Cybersecurity	16
6.8 Binary input and output port	17
6.8.1 Binary input port	17
6.8.2 Binary output port	17
6.9 Transducer analogue input and output port	17

6.9.1	Transducer analogue input port	17
6.9.2	Transducer analogue output port	17
6.10	Input circuit for measurement quantities	17
6.10.1	Analogue voltage port	17
6.10.2	Analogue current port	17
6.10.3	Communication port	18
6.11	Binary output performance (mechanical and static)	18
6.12	Climatic performance	18
6.12.1	General	18
6.12.2	Verification procedure	19
6.12.3	Climatic environmental tests	19
6.13	Mechanical requirements	24
6.13.1	Vibration response and endurance (sinusoidal)	24
6.13.2	Shock response, shock withstand and bump	24
6.13.3	Seismic risk	24
6.14	Pollution	25
6.15	Electromagnetic compatibility (EMC)	25
7	Tests	25
7.1	Test reference conditions	25
7.2	Test overview	26
7.3	Burden measurements	28
7.3.1	Burden for analogue voltage inputs	28
7.3.2	Burden for analogue current inputs	29
7.3.3	Burden for AC power supply	29
7.3.4	Burden for DC power supply	29
7.3.5	Burden for binary input	30
7.4	Type test report content	30
8	Marking, labelling and packaging	31
9	Product documentation and technical data	31
Annex A	(normative) Type testing guidelines	32
Annex B	(informative) Environmental operating locations	37
Bibliography		40

List of Figures

Figure 1	— Ports for measuring relays and protection equipment	7
Figure 2	— Binary output parameters	13
Figure A.1	— Settings selection criteria	33

List of Tables

Table 1	— Normal environmental conditions	10
Table 2	— Contact performance requirements	12
Table 3	— Hot and cold temperatures	14
Table 4	— Dry heat test - Operational	20
Table 5	— Cold test - Operational	21
Table 6	— Dry heat test, storage temperature	22
Table 7	— Cold test, storage temperature	22
Table 8	— Change of temperature test	23
Table 9	— Damp heat steady state test	23
Table 10	— Cyclic temperature with humidity test	24
Table 11	— Test reference conditions	26
Table 12	— Test overview	28
Table B.1	— Operating locations	37
Table B.2	— Climatic conditions	38

Table B.3 — Mechanical conditions.....	38
Table B.4 — EMC conditions.....	39
Table B.5 — Chemically active substance conditions.....	39
Table B.6 — Mechanically active substance conditions	39
Table B.7 — Biological conditions.....	39

FOREWORD

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International, governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

IEC 60255-1 has been prepared by IEC technical committee 95: Measuring relays and protection equipment. It is an International Standard.

This second edition cancels and replaces the first edition published in 2009. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition:

- a) scope of document clarified;
- b) merging units and communications as an integral part of the protection added;
- c) binary output clarification expanded;

- d) environmental operating conditions added ([Annex B](#));
- e) test reference conditions added;
- f) multiple changes to improve understanding across most clauses;
- g) derating by manufacturer added;
- h) safety and EMC tests removed from document and referenced only;
- i) relay setting and type test guidelines modified ([Annex A](#))
- j) battery monitor port and low power instrument transformers added.

The text of this International Standard is based on the following documents:

Draft	Report on voting
95/513/FDIS	95/521/RVD

Full information on the voting for its approval can be found in the report on voting indicated in the above table.

The language used for the development of this International Standard is English.

This document was drafted in accordance with ISO/IEC Directives, Part 2, and developed in accordance with ISO/IEC Directives, Part 1 and ISO/IEC Directives, IEC Supplement, available at www.iec.ch/members_experts/refdocs. The main document types developed by IEC are described in greater detail at www.iec.ch/publications.

A list of all parts in the IEC 60255 series, published under the general title *Measuring relays and protection equipment*, can be found on the IEC website.

The committee has decided that the contents of this document will remain unchanged until the stability date indicated on the IEC website under webstore.iec.ch in the data related to the specific document. At this date, the document will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

INTRODUCTION

The following explains the numbering of documents falling under the responsibility of TC 95:

The numbering of documents follows the following principle:

- common standards start with IEC 60255-XX;
- protection functional standards fall into IEC the 60255-1XX series.

The IEC 60255 series consists of the following parts:

a) Common standards:

Part 1: Common requirements

Part 21: Vibration, shock, bump and seismic tests

Part 24: Common format for transient data exchange (COMTRADE) for power systems

Part 26: Electromagnetic compatibility requirements

Part 27: Product safety requirements

b) Protection functional standards:

Part 1XX: Functional requirements

NOTE The last two digits of the part of the proposed functional standard new numbering correspond to function numbers as established in IEEE Std C37.2™-2008 [3]¹.

1 Numbers in square brackets refer to the [Bibliography](#).

Australian/New Zealand Standard

Measuring relays and protection equipment

Part 1: Common requirements (IEC 60255-1:2022 (ED. 2.0) MOD)

1 Scope

This part of IEC 60255 specifies common rules and requirements applicable to measuring relays and protection equipment, including any combination of equipment to form a distributed protection scheme for power system protection such as control, monitoring and process interface equipment, to obtain uniformity of requirements and tests. This document covers the main technologies in use today; other emerging technologies present specific [EMC](#) and safety issues but the philosophy in this document will be applied.

All measuring relays and protection equipment used for protection within the power system environment are covered by this document. Other documents in this series can define their own requirements which in such cases take precedence. The typical locations for measuring relays and protection equipment are where protection of electrical equipment is required: generally power stations, substations and industrial locations.

Measuring relays and protection equipment installed in special applications (marine, railways, aerospace, explosive atmospheres, computer centres, etc.) could be enhanced by additional requirements required by that application.

2 Normative references

The following documents are referred to in the text in such a way that some or all of their content constitutes requirements of this document. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

NATIONAL VARIATIONS

1. After the first paragraph, *add* the following:

The Australian/New Zealand Standards listed below are modified adoptions of, or not equivalent to, the IEC normative references and are required for the application of this document. All references in the source text to those IEC normative references shall be replaced by references to the corresponding Australian or Australian/New Zealand Standards.

Australian or Australian/New Zealand Standards that are identical adoptions of international normative references may be used interchangeably.

2. *Delete* "IEC 60068-2-1, *Environmental testing – Part 2-1: Tests - Test A: Cold*" and *replace* with the following:

AS 60068.2.1, *Environmental testing, Part 2.1: Tests - Test A: Cold (IEC 60068-2-1:2007 (ED. 6.0) MOD)*

3. *Delete* "IEC 60068-2-2, *Environmental testing – Part 2-2: Tests - Test B: Dry heat*" and *replace* with the following:

AS 60068.2.2, *Environmental testing, Part 2.2: Tests - Test B: Dry heat (IEC 60068-2-2:2007 (ED. 5.0) MOD)*

4. *Delete* "IEC 60068-2-14, *Environmental testing – Part 2-14: Tests - Test N: Change of temperature*" and *replace* with the following:

AS 60068.2.14:2023 *Environmental testing, Part 2.14: Tests - Test N: Change of temperature (IEC 60068-2-14:2009 (ED. 6.0) MOD)*