

Australian Standard™

**High-voltage/low-voltage prefabricated
substations**



This Australian Standard was prepared by Committee EL-007, Power Switchgear. It was approved on behalf of the Council of Standards Australia on 11 April 2005. This Standard was published on 15 July 2005.

The following are represented on Committee EL-007:

Australian British Chamber of Commerce
Australian Electrical and Electronic Manufacturers Association
Energy Networks Association
Engineers Australia
Testing interests (Australia)

Keeping Standards up-to-date

Standards are living documents which reflect progress in science, technology and systems. To maintain their currency, all Standards are periodically reviewed, and new editions are published. Between editions, amendments may be issued. Standards may also be withdrawn. It is important that readers assure themselves they are using a current Standard, which should include any amendments which may have been published since the Standard was purchased.

Detailed information about Standards can be found by visiting the Standards Web Shop at www.standards.com.au and looking up the relevant Standard in the on-line catalogue.

Alternatively, the printed Catalogue provides information current at 1 January each year, and the monthly magazine, *The Global Standard*, has a full listing of revisions and amendments published each month.

Australian Standards™ and other products and services developed by Standards Australia are published and distributed under contract by SAI Global, which operates the Standards Web Shop.

We also welcome suggestions for improvement in our Standards, and especially encourage readers to notify us immediately of any apparent inaccuracies or ambiguities. Contact us via email at mail@standards.org.au, or write to the Chief Executive, Standards Australia, GPO Box 476, Sydney, NSW 2001.

This Standard was issued in draft form for comment as DR 05011.

Australian Standard™

**High-voltage/low-voltage prefabricated
substations**

First published as AS 61330—2005.

COPYRIGHT

© Standards Australia

All rights are reserved. No part of this work may be reproduced or copied in any form or by any means, electronic or mechanical, including photocopying, without the written permission of the publisher.

Published by Standards Australia, GPO Box 476, Sydney, NSW 2001, Australia

ISBN 0 7337 6744 3

PREFACE

This Standard was prepared by the Standards Australia Committee EL-007, Power Switchgear.

The objective of this Standard is to ensure that prefabricated substations meet the needs of users in the areas of high-voltage and Low-voltage.

This Standard is identical with, and has been reproduced from, IEC 61330 Ed. 1.0 (1995), *High-voltage/low-voltage prefabricated substations*.

As this Standard is reproduced from an International Standard, the following applies:

- (a) Its number does not appear on each page of text and its identity is shown only on the cover and title page.
- (b) In the source text 'this international standard' should read 'this Australian Standard'.
- (c) A full point should be substituted for a comma when referring to a decimal marker.
- (d) Any French text on figures should be ignored.

The terms 'normative' and 'informative' are used to define the application of the annex to which they apply. A normative annex is an integral part of a standard, whereas an informative annex is only for information and guidance.

CONTENTS

	<i>Page</i>
1 General.....	1
1.1 Scope	1
1.2 Normative references.....	1
1.3 Definitions.....	3
2 Service conditions.....	5
2.1 Normal service conditions.....	5
2.2 Special service conditions.....	5
3 Requirements for components.....	6
4 Ratings	6
4.1 Rated voltages.....	7
4.2 Rated insulation levels.....	7
4.3 Rated frequency and number of phases.....	7
4.4 Rated normal currents and temperature rise	7
4.5 Rated short-time withstand currents.....	7
4.6 Rated peak withstand currents.....	7
4.7 Rated duration of short circuit.....	8
4.8 Rated supply voltage of operating devices and auxiliary circuits	8
4.9 Rated supply frequency of operating devices and auxiliary circuits	8
4.10 Rated maximum power of the prefabricated substation	8
4.11 Rated class of enclosure.....	8
5 Design and construction.....	8
5.1 Earthing.....	8
5.2 Auxiliary equipment	9
5.3 Nameplate	9
5.4 Degree of protection and internal fault.....	9
5.5 Enclosure	11
5.6 Sound emission	13
6 Type tests.....	13
6.1 Dielectric tests.....	13
6.2 Temperature-rise tests.....	16
6.3 Short-time and peak withstand current tests on earthing circuits	18
6.4 Functional tests	18
6.5 Verification of the degree of protection.....	18
6.6 Mechanical tests.....	18
7 Routine tests.....	19
7.1 Voltage withstand tests on auxiliary circuits	19
7.2 Functional tests	19
7.3 Verification of correct wiring.....	19
7.4 Tests after assembly on site	19
8 Guide to the selection of prefabricated substations for service.....	19

	<i>Page</i>
9 Information to be given with enquiries, tenders and orders	20
9.1 Information with enquiries and orders	20
9.2 Information with tenders.....	20
10 Rules for transport, erection, operation and maintenance.....	21
10.1 Conditions during transport, storage and erection	21
10.2 Operation.....	22
10.3 Maintenance	22
Annex A (normative) Method for testing the prefabricated substation under conditions of arcing due to an internal fault.....	24
Annex B (normative) Test to verify the sound level of a prefabricated substation	32
Annex C (normative) Mechanical impact test	34
Annex D (informative) Rating of transformers in an enclosure	36

INTRODUCTION

Prefabricated substations are defined as type-tested equipment comprising transformer, low-voltage and high-voltage switchgear, connections and auxiliary equipment in an enclosure to supply low-voltage energy from a high-voltage system. These substations are in locations accessible to the public and should ensure safety for persons according to the specified service conditions.

This means that in addition to specified characteristics, ratings and relevant test procedures, particular attention has been paid to specifications concerning the protection of persons. This protection is ensured by use of type-tested components and suitable design and construction of the enclosure.

NOTES

STANDARDS AUSTRALIA

Australian Standard**High-voltage/low-voltage prefabricated substations**

1 General**1.1 Scope**

This International Standard specifies the service conditions, rated characteristics, general structural requirements and test methods of prefabricated substations, which are cable connected, to be operated from inside or outside for alternating current of primary rated voltages above 1 kV and up to and including 52 kV*, and for a transformer of maximum power 1 600 kVA, for service frequencies up to and including 60 Hz for outdoor installation in locations with public accessibility.

Prefabricated substations can be situated at ground level or partially or completely below ground level.

As no basic generally accepted IEC or ISO Standards are available concerning ageing or corrosion, requirements covering these aspects are not included in this Standard.

1.2 Normative references

The following normative documents contain provisions which, through reference in the text, constitute provisions of this International Standard. At the time of publication, the editions indicated were valid. All normative documents are subject to revision, and parties to agreements based on this International Standard are encouraged to investigate the possibility of applying the most recent editions of the normative documents indicated below. Members of IEC and ISO maintain registers of currently valid International Standards.

References to international standards that are struck through in this clause are replaced by references to Australian Standards that are listed immediately thereafter and identified by shading. Any Australian Standard that is identical to the International Standard it replaces is identified as such.

~~IEC 60050-151:2001, *International Electrotechnical Vocabulary — Part 151: Electrical and magnetic devices*~~

AS 1852.151, *International Electrotechnical Vocabulary Part 151: Electrical and magnetic devices*

~~IEC 60050-441:1984, *International Electrotechnical Vocabulary (IEV) — Chapter 441: Switchgear, controlgear and fuses*~~

AS 1852.441, *International Electrotechnical Vocabulary (IEV), Part 441: Switchgear, controlgear and fuses* (identical to IEC 60050-441:1984)

~~IEC 60060-1:1989, *High-voltage test techniques — Part 1: General definitions and test requirements*~~

* The rated voltage on the secondary side should not exceed 1 kV.