



**ANSI C37.54-2023**

**American National Standard  
for Alternating Current  
High-Voltage Circuit Breakers  
Applied in Metal-Enclosed Switchgear—  
Conformance Test Procedures**

Secretariat:

**National Electrical Manufacturers Association**

August 3, 2023

**American National Standards Institute, Inc.**

## NOTICE AND DISCLAIMER

The information in this publication was considered technically sound by the consensus of persons engaged in the development and approval of the document at the time it was developed. Consensus does not necessarily mean that there is unanimous agreement among every person participating in the development of this document.

ANSI standards and guideline publications, of which the document contained herein is one, are developed through a voluntary consensus standards development process. This process brings together volunteers and/or seeks out the views of persons who have an interest in the topic covered by this publication. While NEMA administers the process to promote fairness in the development of consensus, it does not write the document and it does not independently test, evaluate, or verify the accuracy or completeness of any information or the soundness of any judgments contained in its standards and guideline publications.

NEMA disclaims liability for any personal injury, property, or other damages of any nature whatsoever, whether special, indirect, consequential, or compensatory, directly or indirectly resulting from the publication, use of, application, or reliance on this document. NEMA disclaims and makes no guaranty or warranty, express or implied, as to the accuracy or completeness of any information published herein, and disclaims and makes no warranty that the information in this document will fulfill any of your particular purposes or needs. NEMA does not undertake to guarantee the performance of any individual manufacturer or seller's products or services by virtue of this standard or guide.

In publishing and making this document available, NEMA is not undertaking to render professional or other services for or on behalf of any person or entity, nor is NEMA undertaking to perform any duty owed by any person or entity to someone else. Anyone using this document should rely on his or her own independent judgment or, as appropriate, seek the advice of a competent professional in determining the exercise of reasonable care in any given circumstances. Information and other standards on the topic covered by this publication may be available from other sources, which the user may wish to consult for additional views or information not covered by this publication.

NEMA has no power, nor does it undertake to police or enforce compliance with the contents of this document. NEMA does not certify, test, or inspect products, designs, or installations for safety or health purposes. Any certification or other statement of compliance with any health or safety-related information in this document shall not be attributable to NEMA and is solely the responsibility of the certifier or maker of the statement.

# AMERICAN NATIONAL STANDARD

Approval of an American National Standard requires verification by ANSI that the requirements for due process, consensus, and other criteria for approval have been met by the standards developer.

Consensus is established when, in the judgment of the ANSI Board of Standards Review, substantial agreement has been reached by directly and materially affected interests. Substantial agreement means much more than a simple majority, but not necessarily unanimity. Consensus requires that all views and objections be considered, and that a concerted effort be made toward their resolution.

The use of American National Standards is completely voluntary; their existence does not in any respect preclude anyone, whether he has approved the standards or not, from manufacturing, marketing, purchasing, or using products, processes, or procedures not conforming to the standards.

The American National Standards Institute does not develop standards and will in no circumstances give an interpretation of any American National Standard. Moreover, no person shall have the right or authority to issue an interpretation of an American National Standard in the name of the American National Standards Institute. Requests for interpretations should be addressed to the secretariat or sponsor whose name appears on the title page of this standard.

Caution Notice: This American National Standard may be revised or withdrawn at any time. The procedures of the American National Standards Institute require that action be taken periodically to reaffirm, revise, or withdraw this standard. Purchasers of American National Standards may receive current information on all standards by calling or writing the American National Standards Institute.

Published by

**National Electrical Manufacturers Association**  
**1300 North 17th Street, Rosslyn, VA 22209**

© Copyright 2023 by National Electrical Manufacturers Association  
All rights reserved including translation into other languages, reserved under the Universal Copyright Convention, the Berne Convention for the Protection of Literary and Artistic Works, and the International and Pan American Copyright Conventions.

No part of this publication may be reproduced in any form, in an electronic retrieval system or otherwise, without the prior written permission of the publisher.

Printed in the United States of America

**This page intentionally left blank.**

# Contents

- Foreword ..... v
- 1 General ..... 1**
  - 1.1 Scope ..... 1
    - 1.1.1 Scope and Objectives ..... 1
    - 1.1.2 Application..... 1
    - 1.1.3 Installations Not Covered ..... 1
  - 1.2 Definitions ..... 1
    - 1.2.1 Design Tests (Type Tests)..... 1
    - 1.2.2 Production Tests (Routine Tests) ..... 2
    - 1.2.3 Conformance Tests..... 2
  - 1.3 Referenced Standards ..... 2
- 2 General Test Conditions..... 3**
- 3 Conformance Tests..... 3**
  - 3.1 General ..... 3
    - 3.1.1 Tests ..... 3
    - 3.1.2 Coordination with Other Conformance Test Standards ..... 3
    - 3.1.3 Coordination with Design Test Standards ..... 3
    - 3.1.4 Test Specimen ..... 3
    - 3.1.5 Requirements for Circuit Breakers Tested to Earlier Versions of ANSI C37.54 ..... 3
  - 3.2 Test Requirements..... 3
    - 3.2.1 Test Schedules (Table 1)..... 4
    - 3.2.2 Sequence of Test Schedules ..... 5
    - 3.2.3 Severity of Tests ..... 5
    - 3.2.4 Condition Assessments ..... 5
  - 3.3 Test Arrangements..... 6
    - 3.3.1 Test Enclosures ..... 6
    - 3.3.2 Grounding of Test Enclosures ..... 6
  - 3.4 Grouping of Ratings for Test Purposes..... 7
    - 3.4.1 Identified Groups..... 7
    - 3.4.2 Commonalities of Designs and Tests ..... 8
  - 3.5 Dielectric Withstand Tests ..... 8
    - 3.5.1 Power Frequency Withstand Voltage Tests..... 8
    - 3.5.2 Lightning Impulse Withstand Voltage Tests..... 8
    - 3.5.3 Performance..... 9
  - 3.6 Continuous Current Carrying Tests ..... 9
    - 3.6.1 Test ..... 9
  - 3.7 Mechanical Endurance and Operation Tests..... 9
    - 3.7.1 Mechanical Endurance Test ..... 10
    - 3.7.2 Evaluation ..... 10
  - 3.8 Load Current Switching Tests (Conditional) ..... 11
    - 3.8.1 Description of Tests ..... 11
    - 3.8.2 Performance..... 11
  - 3.9 Short-Time Current and Peak Current Withstand Tests ..... 11
    - 3.9.1 Description of Test ..... 11
    - 3.9.2 Performance..... 12
  - 3.10 Short-Circuit Current Tests ..... 14
    - 3.10.1 Description of Tests ..... 14

<b>4</b>	<b>Circuit Breaker Auxiliary Devices .....</b>	<b>14</b>
4.1	General .....	14
4.2	Auxiliary Switches .....	15
4.2.1	Categories of Auxiliary Switches.....	15
4.2.2	Ratings and Capabilities .....	15
4.2.3	Auxiliary Switch Tests .....	15
4.3	Other Components and Features .....	18
4.3.1	Circuit Breakers Components and Features.....	18
4.3.2	Insulating Materials .....	18
<b>5</b>	<b>Treatment of Failures.....</b>	<b>18</b>
5.1	Failure During Test.....	18
5.2	Failure and Corrective Measures Description.....	18
5.3	Failure Causes .....	18
5.3.1	Corrective Action Not Affecting Prior Test Results .....	19
5.3.2	Corrective Action Affecting Prior Test Results.....	19
<b>6</b>	<b>Production Tests.....</b>	<b>19</b>
6.1	Routine Tests .....	19
6.2	Production Tests for Conformance .....	19
<b>7</b>	<b>Production Monitoring and Product Retest Requirements .....</b>	<b>19</b>
7.1	General .....	19
7.2	Production Monitoring .....	20
7.3	Product Retest Requirements.....	20
7.3.1	Retests .....	20
7.3.2	Retest Intervals .....	20
7.3.3	Identified Group.....	20
<b>8</b>	<b>Conformance Test Records .....</b>	<b>21</b>
8.1	Records of Tests .....	21
8.2	To Qualify Other Identified Groups .....	21
8.2.1	Considering Whether Tests May Be Properly Extended .....	21

## Tables

Table 1	Test Schedules.....	5
Table 2	Typical Groupings of Ratings for Test Purposes (See 3.4.1).....	7
Table 3	Test Duties <sup>1</sup> .....	13
Table 4	Auxiliary Switch Tests.....	17
Table 5	Retest Intervals for Typical Test Groups (Example) .....	22
Table 6	Retest Intervals for Combined Groups (Example) .....	23

## Figures

Figure 1	Retest Flow Chart.....	22
----------	------------------------	----

## Foreword

**(This Foreword is not part of American National Standard C37.54-2023.)**

Major revisions have been made in this edition to coordinate with revisions to IEEE C37.04™, which now incorporates the preferred ratings from IEEE C37.06™ (now withdrawn), IEEE C37.09™, and IEEE C37.20.2™. Test procedures in IEEE C37.09 have been harmonized with those in IEC 62271-100 and these new test procedures are incorporated here.

Since this edition eliminates the voltage range factor, circuit breakers with  $K \geq 1.0$  that may be produced after the approval date of this standard should have conformance tests conducted in accordance with the procedures in the 1996 edition of C37.54.

This standard was developed to describe selected tests and procedures to demonstrate conformance in accordance with clause 4 of IEEE C37.09-2018. The scope of this standard is limited to Conformance Test Procedures for Alternating Current High-Voltage Circuit Breakers Applied in Metal-Enclosed Switchgear—Conformance Test Procedures. To facilitate its use and to permit timely revisions based on experience, this document has been prepared.

This standard is one of several in a series of test procedure standards for conformance testing of switchgear products. While this standard is written for general guidance, performance criteria are established so that this standard can be adopted as the basis for certification of identified circuit breakers for use in installations subject to regulation by public authorities and similar agencies concerned with law ordinances, regulations, administrative orders, and similar instruments. It is noted that certain utility installations continue to be excluded from the scope of this standard as a result of historical discussions among representatives from EEI and NEMA.

Suggestions for improvements are welcome and should be sent to the National Electrical Manufacturers Association, 1300 North 17<sup>th</sup> Street, Suite 900, Rosslyn, VA 22209.

This standard was processed and approved for submittal to ANSI by Accredited Standards Committee on Power Switchgear C37. Committee approval of the standard does not necessarily imply that all committee members voted for its approval. At the time of its approval, the C37 Committee had the following members:

Individual	Representing Organization
Alexander, Roy	RWA Engineering LLC
Barnhart, Paul	UL LLC
Edwards, Doug	Siemens Industry, Inc.
Leach, John	Consultant
Moser, Darryl	ABB Inc.
Savulyak, Victor	KEMA-Powertest, LLC
Schneider, Carl	Schneider Electric
Sullivan, Paul	DuPont Engineering
Wactor, Michael	Powell Industries, Inc.
Webb, John	ABB Inc.
Weitzel, Mike	Bechtel Corporation
Wilkie, Eddie	Eaton
Woodyard, Terrance	Siemens Industry, Inc.
Zia, Danish	UL LLC



## **For Alternating Current High-Voltage Circuit Breakers Applied in Metal-Enclosed Switchgear—Conformance Test Procedures**

### **1 General**

#### **1.1 Scope**

##### **1.1.1 Scope and Objectives**

When conformance tests are required, this standard specifies tests to demonstrate that the circuit breaker being tested conforms with the ratings assigned to it by the manufacturer in accordance with IEEE C37.04. Preferred values of the ratings are listed in clause 6 of IEEE C37.04; other values may be assigned to the circuit breaker by the manufacturer where supported by a complete set of type tests supporting these alternative values. Conformance tests according to this standard must utilize the assigned rated values from the type testing. As a requirement of conformance testing, the circuit breaker shall have completed the design testing requirements of IEEE C37.09. If IEEE C37.09 tests have not been previously performed, the tests required by IEEE C37.09 beyond tests described by this standard may be performed concurrently with conformance testing.

Note: Additional tests per IEEE C37.09 need not be witnessed by the certifying party.

##### **1.1.2 Application**

This standard applies to alternating current high-voltage circuit breakers rated above 1000 volts used as removable elements in metal-clad switchgear assemblies in accordance with IEEE C37.20.2 and removable or stationary-mounted elements in metal-enclosed switchgear assemblies in accordance with IEEE C37.20.3.

##### **1.1.3 Installations Not Covered**

This standard may not apply to installations under the exclusive control of electric utilities for the purpose of communication, or metering, or for the generation, control, transformation, transmission, and distribution of electric energy located in buildings used exclusively by utilities for such purposes or located outdoors on property owned or leased by the utility or on public highways, streets, roads, etc., or outdoors by established rights on private property.

### **1.2 Definitions**

The definitions of terms contained in this standard, or in other standards referred to in this standard, are not intended to embrace all legitimate meanings of the terms. They are applicable only to the subject treated in this standard.

If a term is not defined in this standard, the definition in IEEE C37.20.10 or IEEE C37.100.5 applies. An asterisk (\*) following a definition indicates that the definition in this standard is not contained in either IEEE C37.20.10 or IEEE C37.100.5, while a dagger (†) indicates that the definition differs from that in IEEE C37.20.10 or IEEE C37.100.5.

#### **1.2.1 Design Tests (Type Tests)**

Tests made by the manufacturer to determine the adequacy of the design of a particular type, style, or model of equipment or its component parts to meet its assigned ratings and to operate satisfactorily under