



BSI Standards Publication

Fire tests for building elements and components — Fire testing of service installations

Part 3: Single component penetration seals — Guidance on the construction and use of test configurations and simulated services to characterise sealing materials

NO COPYING WITHOUT BSI PERMISSION EXCEPT AS PERMITTED BY COPYRIGHT LAW

National foreword

This Published Document is the UK implementation of ISO/TR 10295-3:2012.

The UK participation in its preparation was entrusted by Technical Committee FSH/22, Fire resistance tests, to Panel FSH/22/-/3, Fire resistance tests for fire penetration and seals.

A list of organizations represented on this committee can be obtained on request to its secretary.

This publication does not purport to include all the necessary provisions of a contract. Users are responsible for its correct application.

© The British Standards Institution 2013

Published by BSI Standards Limited 2013

ISBN 978 0 580 82775 4

ICS 13.220.50; 91.140.01

Compliance with a British Standard cannot confer immunity from legal obligations.

This Published Document was published under the authority of the Standards Policy and Strategy Committee on 30 April 2013.

Amendments issued since publication

Amd. No.	Date	Text affected
-----------------	-------------	----------------------

TECHNICAL REPORT

ISO/TR 10295-3

First edition
2012-08-01

Fire tests for building elements and components — Fire testing of service installations —

Part 3:

Single component penetration seals — Guidance on the construction and use of test configurations and simulated services to characterise sealing materials

*Essais au feu pour les éléments et composants de bâtiment — Essai au
feu des installations de service —*

*Partie 3: Joints de pénétration à composant unique — Lignes directrices sur
la construction et l'utilisation des configurations d'essai et des processus de
simulation permettant de caractériser les matériaux d'étanchéité*



Reference number
ISO/TR 10295-3:2012(E)

© ISO 2012



COPYRIGHT PROTECTED DOCUMENT

© ISO 2012

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either ISO at the address below or ISO's member body in the country of the requester.

ISO copyright office
Case postale 56 • CH-1211 Geneva 20
Tel. + 41 22 749 01 11
Fax + 41 22 749 09 47
E-mail copyright@iso.org
Web www.iso.org

Published in Switzerland

Contents

Page

Foreword	iv
Introduction	v
1 Scope	1
2 Normative references	2
3 Terms and definitions	2
4 Test equipment	3
5 General performance criteria	3
6 Guidance on test configurations and procedures	4
7 Test procedures	4
7.1 Test configuration A — Size of unsupported free area of penetration seal	5
7.2 Test configuration B — Thermal diffusivity of the conductor / penetration	6
7.3 Test configuration C	7
7.4 Test configuration D — When multiple simulated services are being tested	8
7.5 Test procedure E	8
7.6 Test procedure F	8
7.7 Test procedure G	9
7.8 Test procedure H	9
8 Deriving the field of application by judgemental analysis	9
8.1 Analysis using test configuration A	9
8.2 Analysis using test configuration B	9
8.3 Analysis using test configuration C	10
8.4 Analysis using test configuration D	10
9 Deriving the field of application by mathematical analysis	10
9.1 Use of the 3-D interpolation method to predict the extended field of application	10
Annex A (informative) Determining the extended field of application	12
Annex B (informative) Example of the application of the principles of 3-D interpolation to the establishment of the extended application of penetrating sealing system	13
Annex C (informative) 3-D interpolation method of analysis	16

Foreword

ISO (the International Organization for Standardization) is a worldwide federation of national standards bodies (ISO member bodies). The work of preparing International Standards is normally carried out through ISO technical committees. Each member body interested in a subject for which a technical committee has been established has the right to be represented on that committee. International organizations, governmental and non-governmental, in liaison with ISO, also take part in the work. ISO collaborates closely with the International Electrotechnical Commission (IEC) on all matters of electrotechnical standardization.

International Standards are drafted in accordance with the rules given in the ISO/IEC Directives, Part 2.

The main task of technical committees is to prepare International Standards. Draft International Standards adopted by the technical committees are circulated to the member bodies for voting. Publication as an International Standard requires approval by at least 75 % of the member bodies casting a vote.

In exceptional circumstances, when a technical committee has collected data of a different kind from that which is normally published as an International Standard ("state of the art", for example), it may decide by a simple majority vote of its participating members to publish a Technical Report. A Technical Report is entirely informative in nature and does not have to be reviewed until the data it provides are considered to be no longer valid or useful.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. ISO shall not be held responsible for identifying any or all such patent rights.

ISO/TR 10295-3 was prepared by Technical Committee ISO/TC 92, *Fire safety*, Subcommittee SC 2, *Fire containment*.

ISO/TR 10295 consists of the following parts, under the general title *Fire tests for building elements and components — Fire testing of service installations*:

- *Part 1: Penetration seals*
- *Part 2: Linear joint (gap) seals*
- *Part 3: Single component penetration seals — Guidance on the construction and use of test configurations and simulated services to characterize sealing materials*

Introduction

This Technical Report describes a range of standard test configurations and associated testing procedures designed to determine the relevant characteristics of a penetration seal composed of one material when subjected to the standard fire exposure conditions outlined in ISO 834-1. It is used in conjunction with ISO 10295-1 in order to establish relationships between the parameters that influence the performance of the seal in use. The test data generated by this procedure are intended to assist in the classification of penetration seals based on their intended use and fire resistance under the specified acceptance criteria of this part of ISO 10295, i.e. their field of extended application by use of the methodology given in ISO/TR 12470.

In addition, the methodology is recommended to manufacturers for use when developing new sealing products, as it provides a way of establishing the limiting characteristics of the sealing system in a quantifiable manner. This report describes a procedure intended to be followed utilizing a well selected series of test configurations, which can be used to generate a data set to characterize the fire sealing capabilities of a single component penetration seal material. The data set is intended to contain enough information to provide users with engineering data to determine the suitability of the material in applications other than that in which the material was originally tested.

A wide variety of product types is used to reinstate the integrity of a fire-separating element when penetrated by a service or group of services. These product types include, for example

- a) soft fillers (sealants or 'mastics');
- b) semi-rigid intumescent strip materials on their own or in combination with elastomeric foam materials;
- c) rigid fibrous batts;
- d) rigid board systems;
- e) rigid fillers (epoxies or cementitious);
- f) cementitious plasters/clay/vermiculite systems.

A wide variety of materials is used to "firestop" penetrations through which building services pass. These materials all fail at some time during a fire, but the nature of the method of failure; melting, slumping, charring through etc., needs to be fully understood if a field of application is to be determined with any confidence. Standard configurations and their associated test procedures need, in due course, to be derived to replicate the appropriate failure modes and also to increase the range of simulated services so the range of tests and configurations described in this part of ISO 10295 are not exhaustive.

Fire tests for building elements and components — Fire testing of service installations —

Part 3: Single component penetration seals — Guidance on the construction and use of test configurations and simulated services to characterize sealing materials

1 Scope

This part of ISO 10295 provides guidance in respect of a structured method of characterizing the penetrating seal under test utilizing a series of defined parameters, each one being determined by the use of a selected series of test configurations in conjunction with simulated services. The level of characterization being sought is dependent upon the classification requirement of the system, which in turn determines the complexity of the test program. It is also intended the test method addresses the influence the supporting construction has on the performance of the seal system.

The methods described apply to the determination of data relating to single component penetration seals where the penetration service does not melt out within the appropriate period of exposure to a fully developed fire.

The selection of the appropriate system depends upon many factors. Of particular importance is the size of the penetration, since penetration seal systems are frequently penetration size (or size range) specific.

This is a guidance document, its purpose being to determine the critical parameters relating to the performance of the seal being evaluated. Such parameters can then be used as a basis for interpolation and/or extrapolation of the seal's performance. The procedures used have been developed utilizing small square penetrations, single component penetration seals, and cylindrical conductors; however it is possible to generate a similar series of tests using rectangular cross-section conductors if this is more appropriate to end use.

This part of ISO 10295 provides a structured approach designed to establish

- the mode of failure;
- the parameters critical to the performance of the penetration seal under test.

The mode of failure and critical parameters are ascertained using test configurations appropriate to the potential performance of the product, in conjunction with clearly defined standard penetrations.

The results gained from the application of this technical report are designed to assist a suitably qualified person to develop a direct and extended field of application for the penetration seal under test using in particular, the principles and methodology given in ISO/TR 12470. Using the field(s) of application so generated, it should be possible to classify the penetration seal, thus facilitating its incorporation into specifications.

The test configurations recommended in this part of ISO 10295 are not appropriate for evaluating multi-component penetration seals.

This part of ISO 10295 is not appropriate for characterizing all types of penetration seals, e.g. pipe closers/collars and some gland systems, for which evaluation using ISO 10295-1 is more appropriate.

This part of ISO 10295 does not address the distance required between services that can generate their own heat. When a live service is being evaluated, it is necessary to give consideration to the distance required between penetrations.